

# photovoltaic system (o Paulo utilizou no TCC dele)

Carlos Frederico Meschini Almeida

[cfmalmeida@usp.br](mailto:cfmalmeida@usp.br)

11 987822361

# MEU TCC COM O OPENDSS


Referência:

<https://www.youtube.com/playlist?list=PLhdRxvt3nJ8xE9IZL2hgk8RqFDstTZB8h>

# OBJETIVOS

- Simulate 13-bus distribution system in static mode
- Evaluate the power, voltage and current of the system loads
- Describe the power flow
- Time-series simulation (simulation over a day with one hour time interval)
- time-series static with and without resources (PV systems)
- Model a storage system in the network

# DOWNLOAD



# ARQUIVO MASTER

The image shows a screenshot of the OpenDSS software interface. The main window displays a script file named "MASTER\_RedeTeste13Barras.dss". The script content includes comments and redirections to various sub-files. A file explorer window is overlaid on the right, showing the "DSSFiles" folder. The file "MASTER\_RedeTeste13Barras.dss" is highlighted in the file list, and a blue arrow points to it from the left. The file explorer also shows other files like "capacitors.dss", "command\_monitor\_pv.dss", etc.

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault Vsource Base Frequency = 60 Hz

Version 9.1.0.1 (64-bit build)

```
//-----//  
// Escola Politécnica da USP  
// PEA  
// Autor  
// Nome: Paulo Radatz  
// NUSP: 6905560  
//-----//  
// Modelagem da rede teste IEEE 13 barras  
//-----//  
// No Apêndice A do meu TCC se encontra toda a explicação para rodar os diferentes casos de teste  
//-----//  
// Reinicia o programa  
Clear  
//-----//  
// Files que descrevem o circuito  
Redirect substacao.dss  
Redirect linecodes.dss  
Redirect lines.dss  
Redirect loadshape.dss  
Redirect loads.dss  
Redirect capacitors.dss  
Redirect transformer_sub.dss  
Redirect transformer.dss  
Redirect regulators.dss  
Redirect switches.dss  
  
!Redirect wind_power.dss  
!Redirect wind_control.dss  
  
!Redirect pvsystemexample.dss  
!Redirect volt_var_pv.dss  
  
Redirect storage_power.dss
```

Open DSS Script File

Paulo\_Example > DSSFiles

Name	Date modified
capacitors.dss	1/8/2016 2:33 AM
command_monitor_pv.dss	1/8/2016 2:33 AM
command_monitor_storage.dss	1/8/2016 2:33 AM
command_monitor_sub.dss	1/8/2016 2:33 AM
command_monitor_wind.dss	1/8/2016 2:33 AM
linecodes.dss	1/8/2016 2:33 AM
lines.dss	1/8/2016 2:33 AM
loads.dss	1/8/2016 2:33 AM
loadshape.dss	1/8/2016 2:33 AM
MASTER_RedeTeste13Barras.dss	1/8/2016 2:33 AM
monitor_pv.dss	1/8/2016 2:33 AM
monitor_storage.dss	1/8/2016 2:33 AM

File name: DSS files (\*.dss)

Open

Messages OpenDSS - C:\Program Files\OpenDSS\IEEE13Bus\IEEE13Nodeckt.dss

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault GICsource Base Frequency = 60 Hz

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss Version 9.1.0.1 (64-bit build)

Clear

- Redirect subestacao.dss
- Redirect linecodes.dss
- Redirect lines.dss
- Redirect loadshape.dss
- Redirect loads.dss
- Redirect capacitors.dss
- Redirect transformer\_sub.dss
- Redirect transformer.dss
- Redirect regulators.dss
- Redirect switches.dss

Redirect tensao\_base.dss

```
!Transformer.RegFaseA.Taps=[1.0 1.0]
!Transformer.RegFaseB.Taps=[1.0 1.0]
!Transformer.RegFaseC.Taps=[1.0 1.0]
!Set Controlmode=OFF
!solve maxcontrol=100
```

Right click

- Do Selected **Ctrl+D**
- Save This Window
- Close Window
- Change to this Directory
- Open Selected File
- Edit Selected File
- Change Font...

Main MASTER\_RedeTeste13Barras.dss subestacao.dss linecodes.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss

Summary Results

Memory: 41708K No Active Circuit

Windows taskbar: File Explorer, Firefox, Chrome, Word, PowerPoint, Outlook, DSS, Paint, System tray (Volume, Network, ENG, 8:19 PM 10/8/2020)

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault GICsource Base Frequency = 60 Hz

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss Version 9.1.0.1 (64-bit build)

```
//-----//
// Dados dos arranjos.
// 601
New linecode.601 nphases=3 BaseFreq=60
~ rmatrix = (0.2153 | 0.0969 0.2097 | 0.0982 0.0954 0.2121)
~ xmatrix = (0.6325 | 0.3117 0.6511 | 0.2632 0.2392 0.6430)
~ cmatrix = (10.3833 | -3.2894 9.8228 | -2.0759 -1.2225 9.2936)
~ units=km

// 602
New linecode.602 nphases=3 BaseFreq=60
~ rmatrix = (0.4676 | 0.0982 0.4645 | 0.0969 0.0954 0.4621 )
~ xmatrix = (0.7341 | 0.2632 0.7446 | 0.3117 0.2392 0.7526 )
~ cmatrix = (9.3931 | -1.7828 8.5369 | -2.7862 -1.0859 8.9508)
~ units=km

// 603
New linecode.603 nphases=2 BaseFreq=60
~ rmatrix = (0.8261 | 0.1284 0.8226)
~ xmatrix = (0.8370 | 0.2853 0.8431)
~ cmatrix = (7.7626 | -1.4833 7.6902)
~ units=km

// 604
New linecode.604 nphases=2 BaseFreq=60
~ rmatrix = (0.8226 | 0.1284 0.8261)
~ xmatrix = (0.8431 | 0.2853 0.8370)
~ cmatrix = (7.6902 | -1.4833 7.7626)
~ units=km

// 605
New linecode.605 nphases=1 BaseFreq=60
~ rmatrix = (0.8259)
~ vmatrix = (0.8373)
```

Main MASTER\_RedeTeste13Barras.dss subestacao.dss linecodes.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\linecodes.dss

Summary Results

The screenshot displays the OpenDSS Data Directory interface. The main window shows simulation results for Actor ID # 1, including CPU selection, status (SOLVED), solution mode (Snap), and various system parameters like buses, nodes, and iterations. A list of files to be redirected is shown in the center, with a 'solve' button circled in blue. A blue arrow points from the text 'Ctrl+A and Ctrl+D' to the list of files. Another blue arrow points from the 'solve' button to the 'Redirect tensao\_base.dss' entry. A smaller inset window shows the command script for the simulation, including voltage base settings and control mode parameters.

OpenDSS Data Directory: C:\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault GICsource

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 41  
Control Mode =STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

- Circuit Summary -

Year = 0  
Hour = 0  
Max pu. voltage = 1.0562  
Min pu. voltage = 0.96102  
Total Active Power: 3.56706 MW  
Total Reactive Power: 1.73636 Mvar  
Total Active Losses: 0.112108 MW, (3.143 %)  
Total Reactive Losses: 0.327706 Mvar  
Frequency = 60 Hz  
Mode = Snap  
Control Mode = STATIC  
Load Model = PowerFlow

Clear

- Redirect subestacao.dss
- Redirect linecodes.dss
- Redirect lines.dss
- Redirect loadshape.dss
- Redirect loads.dss
- Redirect capacitors.dss
- Redirect transformer\_sub.dss
- Redirect transformer.dss
- Redirect regulators.dss
- Redirect switches.dss

Redirect tensao\_base.dss

**solve**

!Transformer.RegFaseA.Taps=[1.0 1.0]  
!Transformer.RegFaseB.Taps=[1.0 1.0]  
!Transformer.RegFaseC.Taps=[1.0 1.0]  
!Set Controlmode=OFF

!solve maxcontrol=100

Ctrl+A and Ctrl+D

OpenDSS Data Directory: C:\Users\HP\Desktop

ort Show Visualize Plot Reset Help

Source/Fault GICsource

Example\DSSFiles\MASTER\_RedeTeste13Barras.dss

```
//-----//  
// Configuraç o de tens o de base.  
Set Voltagebases=[115.416.48.69]  
CalcVoltageBases  
BusCoords IEEE13Node_BusXY.csv  
New energymeter.m1 line.650632 1  
//-----//
```

OpenDSS Data Directory: C:\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault GT source

J:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MAS\RedeTeste13Barras.dss

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Snap  
 Number = 100  
 Load Mult = 1.000  
 Devices = 39  
 Buses = 16  
 Nodes = 41  
 Control Mode =STATIC  
 Total Iterations = 11  
 Control Iterations = 3  
 Max Sol Iter = 4

- Circuit Summary -

Year = 0  
 Hour = 0  
 Max pu. voltage = 1.0562  
 Min pu. voltage = 0.96102  
 Total Active Power: 3.56706 MW  
 Total Reactive Power: 1.73636 Mvar  
 Total Active Losses: 0.112108 MW, (3.143 %)  
 Total Reactive Losses: 0.327706 Mvar  
 Frequency = 60 Hz  
 Mode = Snap  
 Control Mode = STATIC  
 Load Model = PowerFlow

Clear



Redirect subestacao.dss  
 Redirect linecodes.dss  
 Redirect lines.dss  
 Redirect loadshape.dss  
 Redirect loads.dss  
 Redirect capacitors.dss  
 Redirect transformer\_sub.dss  
 Redirect transformer.dss  
 Redirect regulators.dss  
 Redirect switches.dss

Redirect tensao\_base.dss

solve

!transformer.RegFaseA.Taps=[1.0 1.0]  
 !transformer.RegFaseB.Taps=[1.0 1.0]  
 !transformer.RegFaseC.Taps=[1.0 1.0]  
 !Set Controlmode=OFF

!solve maxcontrol=100



# ARQUIVO SUMMARY

Este projeto apresenta, inicialmente, a importância da mudança da estrutura atual do setor elétrico brasileiro através da implantação do conceito de redes elétricas inteligentes nos sistemas de distribuição. Nesse cenário é imprescindível a utilização de softwares capazes de dar suporte a essa evolução. No presente trabalho é utilizado o OpenDSS. Com o objetivo de descrever o conteúdo metodológico e verificar as funcionalidades desse software apresenta-se uma forma de construção das matrizes de admitâncias nodais dos elementos de rede, de uma rede completa, a descrição do método utilizado para cálculo de fluxo de potência e, além disso, são apresentados os diferentes modos de cálculo de fluxo de potência e os modelos de geração distribuída disponibilizados pelo software para a simulação da rede teste IEEE 13 barras. Por fim, são apresentados os resultados das simulações realizadas em um sistema de distribuição real com a finalidade de se analisar os níveis de suas tensões. O sistema é modelado no software OpenDSS através de dados fornecidos por uma distribuidora americana de energia elétrica. Esse estudo é realizado em conjunto com o EPRI e tem como principal objetivo atender as demandas de planejamento da distribuidora americana.

# ARQUIVO SUMMARY

The screenshot displays the OpenDSS Data Directory interface. The window title is "OpenDSS Data Directory: C:\". The menu bar includes File, Edit, Do, Set, Make, Export, Show, Visualize, Plot, Reset, and Help. The toolbar contains icons for file operations and simulation. The address bar shows the file path: "J:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss".

The main window is divided into two panes. The left pane shows the results for Actor ID # 1, with several lines highlighted by arrows from the left. The right pane shows a list of redirected files and a solve command.

**Results for Actor ID # 1**

- CPU selected : 0
- Status = SOLVED
- Solution Mode = Snap
- Number = 100
- Load Mult = 1.000
- Devices = 39
- Buses = 16
- Nodes = 41
- Control Mode =STATIC
- Total Iterations = 11
- Control Iterations = 3
- Max Sol Iter = 4

- Circuit Summary -

Year = 0  
 Hour = 0  
 Max pu. voltage = 1.0562  
 Min pu. voltage = 0.96102  
 Total Active Power: 3.56706 MW  
 Total Reactive Power: 1.73636 Mvar  
 Total Active Losses: 0.112108 MW, (3.143 %)  
 Total Reactive Losses: 0.327706 Mvar  
 Frequency = 60 Hz  
 Mode = Snap  
 Control Mode = STATIC  
 Load Model = PowerFlow

**Clear**

- Redirect subestacao.dss
- Redirect linecodes.dss
- Redirect lines.dss
- Redirect loadshape.dss
- Redirect loads.dss
- Redirect capacitors.dss
- Redirect transformer\_sub.dss
- Redirect transformer.dss
- Redirect regulators.dss
- Redirect switches.dss


Redirect tensao\_base.dss

**solve**

- !Transformer.RegFaseA.Taps=[1.0 1.0]
- !Transformer.RegFaseB.Taps=[1.0 1.0]
- !Transformer.RegFaseC.Taps=[1.0 1.0]
- !Set Controlmode=OFF

!solve maxcontrol=100

# ARQUIVOS DE TENSÃO



The screenshot displays the OpenDSS software interface. The title bar indicates the data directory: "OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\". The main menu includes "File", "Show", "Visualize", "Plot", "Reset", and "Help". The "Voltages" menu is open, showing sub-options: "Voltages LN", "Voltages LL", "Voltages LN Nodes", "Voltages LN Elements", and "Voltage LL Nodes". A blue arrow points to the "Voltages" menu item. The left sidebar shows a "Summary" panel with the following text:

```
Results for Actor ID # 1
CPU selected : 0
Status = SOLVED
Solution Mode = Snap
Number = 100
Load Mult = 1.000
Devices = 39
Buses = 16
Nodes = 41
Control Mode =STATIC
Total Iterations = 11
Control Iterations = 3
Max Sol Iter = 4
- Circuit Summary -
Year = 0
Hour = 0
Max pu. voltage = 1.0562
Min pu. voltage = 0.96102
Total Active Power: 3.56706 MW
Total Reactive Power: 1.73636
Mvar
Total Active Losses: 0.112108
MW, (3.143 %)
Total Reactive Losses: 0.327706
Mvar
Frequency = 60 Hz
Mode = Snap
Control Mode = STATIC
Load Model = PowerFlow
```

The bottom status bar shows: "Memory: 43632K", "Circuit Status: SOLVED", and "Total Iterations = 11, Control Iterations = 3, Max Solution Iterations = 4".

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Snap  
 Number = 100  
 Load Mult = 1.000  
 Devices = 39  
 Buses = 16  
 Nodes = 41  
 Control Mode =STATIC  
 Total Iterations = 11  
 Control Iterations = 3  
 Max Sol Iter = 4  
 - Circuit Summary -  
 Year = 0  
 Hour = 0  
 Max pu. voltage = 1.0562  
 Min pu. voltage = 0.96102  
 Total Active Power: 3.56706 MW  
 Total Reactive Power: 1.73636 Mvar  
 Total Active Losses: 0.112108 MW, (3.143 %)  
 Total Reactive Losses: 0.327706 Mvar  
 Frequency = 60 Hz  
 Mode = Snap  
 Control Mode = STATIC  
 Load Model = PowerFlow

Clear

//-----  
 // Files que des

Redirect substa  
 Redirect linecod  
 Redirect lines.ds  
 Redirect loadsh  
 Redirect loads.d  
 Redirect capacit  
 Redirect transfo  
 Redirect regulat  
 Redirect switche

Redirect tensao

solve

IEEE13BARRAS\_VLN - Notepad

File Edit Format View Help

SYMMETRICAL COMPONENT VOLTAGES BY BUS (for 3-phase buses)

Bus	Mag:	V1 (kV)	p.u.	V2 (kV)	%V2/V1	V0 (kV)	%V0/V1
sourcebus	66.4		1	4.835E-008	7.282E-008	4.319E-009	6.505E-009
reg	2.522		1.05	0.01499	0.5944	0.015	0.5947
632	2.44		1.016	0.01216	0.4982	0.02505	1.027
670	2.422		1.009	0.02229	0.92	0.04401	1.817
671	2.392		0.9959	0.04212	1.761	0.08255	3.451
680	2.392		0.9959	0.04212	1.761	0.08255	3.451
633	2.434		1.013	0.01218	0.5006	0.02592	1.065
645	2.408		1.002	0	0	0	0
646	2.403		1	0	0	0	0
692	2.392		0.9958	0.04222	1.765	0.08263	3.455
675	2.387		0.9938	0.04539	1.902	0.08784	3.68
684	2.356		0.981	0	0	0	0
611	2.308		0.961	0	0	0	0
652	2.343		0.9755	0	0	0	0
634	0.2751		0.9928	0.001628	0.5918	0.003319	1.206
650	2.402		1	2.451E-007	1.02E-005	1.842E-007	7.67E-006

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Snap  
 Number = 100  
 Load Mult = 1.000  
 Devices = 39  
 Buses = 16  
 Nodes = 41  
 Control Mode = STATIC  
 Total Iterations = 11  
 Control Iterations = 3  
 Max Sol Iter = 4

- Circuit Summary -

Year = 0  
 Hour = 0  
 Max pu. voltage = 1.0562  
 Min pu. voltage = 0.96102  
 Total Active Power: 3.56706 MW  
 Total Reactive Power: 1.73636 Mvar  
 Total Active Losses: 0.112108 MW, (3.143 %)  
 Total Reactive Losses: 0.327706 Mvar  
 Frequency = 60 Hz  
 Mode = Snap  
 Control Mode = STATIC  
 Load Model = PowerFlow

Clear  
 //-----  
 // Files que des  
 Redirect substa  
 Redirect linecod  
 Redirect lines.ds  
 Redirect loadsh  
 Redirect loads.d  
 Redirect capac  
 Redirect transfo  
 Redirect transfo  
 Redirect regulat  
 Redirect switche  
 Redirect tensao  
 solve

IEEE13BARRAS\_VLL - Notepad

File Edit Format View Help

SYMMETRICAL COMPONENT PHASE-PHASE VOLTAGES BY BUS (for 3-phase buses)

Bus	Mag:	V1 (kV)	p.u.	V2 (kV)	%V2/V1	V0 (kV)	%V0/V1
sourcebus	115		1	3.353E-008	2.916E-008	1.275E-014	1.109E-014
reg	4.368	1.05	0.02596	0.5944	8.198E-016	1.877E-014	
632	4.226	1.016	0.02106	0.4982	3.216E-016	7.608E-015	
670	4.196	1.009	0.0386	0.92	2.542E-016	6.059E-015	
671	4.143	0.9959	0.07295	1.761	4.099E-016	9.894E-015	
680	4.143	0.9959	0.07295	1.761	7.19E-016	1.736E-014	
633	4.216	1.013	0.0211	0.5006	4.099E-016	9.723E-015	
645	2.408	0.5788	0	0	0	0	
646	2.403	0.5776	0	0	0	0	
692	4.143	0.9958	0.07313	1.765	5.084E-016	1.227E-014	
675	4.134	0.9938	0.07862	1.902	7.28E-016	1.761E-014	
684	2.356	0.5664	0	0	0	0	
611	2.308	0.5548	0	0	0	0	
652	2.343	0.5632	0	0	0	0	
634	0.4765	0.9928	0.00282	0.5918	4.019E-017	8.435E-015	
650	4.16		1	4.23E-007	1.017E-005	7.28E-016	1.75E-014

## LINE-GROUND and LINE-LINE VOLTAGES BY BUS &amp; NODE

Bus	Node	VLN (kV)	Angle	pu	Base kV	Node-Node	VLL (kV)	Angle	pu
SOURCEBUS	1	66.395 /_	30.0	1	115.000	1-2	115 /_	60.0	1
-	2	66.395 /_	-90.0	1	115.000	2-3	115 /_	-60.0	1
-	3	66.395 /_	150.0	1	115.000	3-1	115 /_	180.0	1
REG .....	1	2.5368 /_	0.0	1.0562	4.160	1-2	4.3549 /_	29.7	1.0468
-	2	2.4918 /_	-120.0	1.0375	4.160	2-3	4.3549 /_	-89.7	1.0469
-	3	2.5368 /_	120.0	1.0562	4.160	3-1	4.3938 /_	150.0	1.0562
632 .....	1	2.4366 /_	-2.5	1.0145	4.160	1-2	4.234 /_	28.1	1.0178
-	2	2.4715 /_	-121.7	1.029	4.160	2-3	4.2396 /_	-92.4	1.0191
-	3	2.4122 /_	117.8	1.0044	4.160	3-1	4.2055 /_	147.8	1.0109
670 .....	1	2.4118 /_	-3.4	1.0042	4.160	1-2	4.2033 /_	27.8	1.0104
-	2	2.4785 /_	-122.0	1.032	4.160	2-3	4.2252 /_	-93.1	1.0157
-	3	2.3776 /_	117.1	0.98992	4.160	3-1	4.1595 /_	147.1	0.99987
671 .....	1	2.3608 /_	-5.4	0.98295	4.160	1-2	4.1444 /_	27.1	0.99625
-	2	2.4987 /_	-122.4	1.0404	4.160	2-3	4.2058 /_	-94.4	1.011
-	3	2.3179 /_	116.0	0.96506	4.160	3-1	4.0795 /_	145.6	0.98064
680 .....	1	2.3608 /_	-5.4	0.98295	4.160	1-2	4.1444 /_	27.1	0.99625
-	2	2.4987 /_	-122.4	1.0404	4.160	2-3	4.2058 /_	-94.4	1.011
-	3	2.3179 /_	116.0	0.96506	4.160	3-1	4.0795 /_	145.6	0.98064
633 .....	1	2.4293 /_	-2.6	1.0115	4.160	1-2	4.2233 /_	28.1	1.0152
-	2	2.4669 /_	-121.8	1.0271	4.160	2-3	4.2292 /_	-92.4	1.0166
-	3	2.4059 /_	117.8	1.0017	4.160	3-1	4.195 /_	147.8	1.0084
645 .....	2	2.4494 /_	-121.9	1.0198	4.160	2-3	4.2119 /_	-92.3	1.0125
-	3	2.4077 /_	117.8	1.0025	4.160				
646 .....	2	2.4453 /_	-122.0	1.0181	4.160	2-3	4.2016 /_	-92.4	1.01
-	3	2.4028 /_	117.9	1.0004	4.160				
692 .....	1	2.3605 /_	-5.4	0.98283	4.160	1-2	4.1441 /_	27.1	0.99619
-	2	2.4987 /_	-122.4	1.0404	4.160	2-3	4.2057 /_	-94.4	1.011
-	3	2.3177 /_	116.0	0.96498	4.160	3-1	4.0791 /_	145.6	0.98055
675 .....	1	2.3448 /_	-5.6	0.97629	4.160	1-2	4.1339 /_	27.1	0.99372
-	2	2.5043 /_	-122.6	1.0427	4.160	2-3	4.2028 /_	-94.5	1.0103
-	3	2.313 /_	116.0	0.96304	4.160	3-1	4.0667 /_	145.4	0.97756
684 .....	1	2.3562 /_	-5.4	0.98102	4.160				
-	3	2.313 /_	115.9	0.96303	4.160	3-1	4.0696 /_	145.6	0.97828
611 .....	3	2.3082 /_	115.8	0.96102	4.160				
652 .....	1	2.343 /_	-5.3	0.97554	4.160				
634 .....	1	0.27361 /_	-3.3	0.98732	0.480	1-2	0.47656 /_	27.6	0.99283
-	2	0.27949 /_	-122.3	1.0085	0.480	2-3	0.47898 /_	-92.9	0.99787
-	3	0.27231 /_	117.3	0.98262	0.480	3-1	0.47409 /_	147.1	0.9877
650 .....	1	2.4018 /_	0.0	1	4.160	1-2	4.16 /_	30.0	1
-	2	2.4018 /_	-120.0	1	4.160	2-3	4.16 /_	-90.0	1
-	3	2.4018 /_	120.0	1	4.160	3-1	4.16 /_	150.0	1

File Edit Format View Help

## NODE-GROUND VOLTAGES BY CIRCUIT ELEMENT

## Power Delivery Elements

Bus	(node ref)	Phase	Magnitude, kV (pu)	Angle
ELEMENT = "Vsource.SOURCE"				
SOURCEBUS	( 1)	1	66.395 ( 1) /_	30.0
SOURCEBUS	( 2)	2	66.395 ( 1) /_	-90.0
SOURCEBUS	( 3)	3	66.395 ( 1) /_	150.0
-----				
SOURCEBUS	( 0)	0	0 ( 0) /_	0.0
SOURCEBUS	( 0)	0	0 ( 0) /_	0.0
SOURCEBUS	( 0)	0	0 ( 0) /_	0.0
ELEMENT = "Line.650632"				
REG	( 4)	1	2.5368 ( 1.056) /_	0.0
REG	( 5)	2	2.4918 ( 1.037) /_	-120.0
REG	( 6)	3	2.5368 ( 1.056) /_	120.0
-----				
632	( 7)	1	2.4366 ( 1.015) /_	-2.5
632	( 8)	2	2.4715 ( 1.029) /_	-121.7
632	( 9)	3	2.4122 ( 1.004) /_	117.8
ELEMENT = "Line.632670"				
632	( 7)	1	2.4366 ( 1.015) /_	-2.5
632	( 8)	2	2.4715 ( 1.029) /_	-121.7
632	( 9)	3	2.4122 ( 1.004) /_	117.8

File Edit Format View Help

## LINE-LINE VOLTAGES BY BUS &amp; NODE

Bus	Node	VLN (kV)	Angle	pu	Base kV
SOURCEBUS	1-2	115 /_	60.0	1	115.000
-	2-3	115 /_	-60.0	1	115.000
-	3-1	115 /_	180.0	1	115.000
REG .....	1-2	4.3549 /_	29.7	1.0468	4.160
-	2-3	4.3549 /_	-89.7	1.0469	4.160
-	3-1	4.3938 /_	150.0	1.0562	4.160
632 .....	1-2	4.234 /_	28.1	1.0178	4.160
-	2-3	4.2396 /_	-92.4	1.0191	4.160
-	3-1	4.2055 /_	147.8	1.0109	4.160
670 .....	1-2	4.2033 /_	27.8	1.0104	4.160
-	2-3	4.2252 /_	-93.1	1.0157	4.160
-	3-1	4.1595 /_	147.1	0.99987	4.160
671 .....	1-2	4.1444 /_	27.1	0.99625	4.160
-	2-3	4.2058 /_	-94.4	1.011	4.160
-	3-1	4.0795 /_	145.6	0.98064	4.160
680 .....	1-2	4.1444 /_	27.1	0.99625	4.160
-	2-3	4.2058 /_	-94.4	1.011	4.160
-	3-1	4.0795 /_	145.6	0.98064	4.160
633 .....	1-2	4.2233 /_	28.1	1.0152	4.160
-	2-3	4.2292 /_	-92.4	1.0166	4.160
-	3-1	4.195 /_	147.8	1.0084	4.160
645 .....	2-3	4.2119 /_	-92.3	1.0125	4.160
646 .....	2-3	4.2016 /_	-92.4	1.01	4.160
692 .....	1-2	4.1441 /_	27.1	0.99619	4.160
-	2-3	4.2057 /_	-94.4	1.011	4.160
-	3-1	4.0791 /_	145.6	0.98055	4.160
675 .....	1-2	4.1339 /_	27.1	0.99372	4.160
-	2-3	4.2028 /_	-94.5	1.0103	4.160
-	3-1	4.0667 /_	145.4	0.97756	4.160
684 .....	3-1	4.0696 /_	145.6	0.97828	4.160
634 .....	1-2	0.47656 /_	27.6	0.99283	0.480

File Edit View Options Help

Export Show Visualize Plot Reset Help

Result

CNData

Base Frequency = 60 Hz

Voltages

Buses

Currents

Sequence

Powers

Element

Losses

Summary

Buscoords

Fault Currents

Capacity

Overloads

Unservd

Generators

Loads

Node Names

Node Order

Meters

Estimation

Monitors ...

Yprims

Y

Seq Z

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 41  
Control Mode =STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

- Circuit Summary -  
Year = 0  
Hour = 0  
Max pu. voltage = 1.0562  
Min pu. voltage = 0.96102  
Total Active Power: 3.56706 MW  
Total Reactive Power: 1.73636 Mvar  
Total Active Losses: 0.112108 MW, (3.143 %)  
Total Reactive Losses: 0.327706 Mvar  
Frequency = 60 Hz  
Mode = Snap  
Control Mode = STATIC  
Load Model = PowerFlow

Main MASTER\_RedeTeste13Barras.dss

Messages Main

Summary Results

Memory: 40992K

Circuit Status: SOLVED

Total Iterations = 11, Control Iterations = 3, Max Solution Iterations = 4

File Edit Format View Help

```

Bus, BasekV, Node1, Magnitude1, Angle1, pu1, Node2, Magnitude2, Angle2, pu2, Node3, Magnitude3, Angle3, pu3
"SOURCEBUS", 115, 1, 66395.3, 30.0, 1, 2, 66395.3, -90.0, 1, 3, 66395.3, 150.0, 1
"REG", 4.16, 1, 2536.75, 0.0, 1.0562, 2, 2491.77, -120.0, 1.0375, 3, 2536.75, 120.0, 1.0562
"632", 4.16, 1, 2436.61, -2.5, 1.0145, 2, 2471.5, -121.7, 1.029, 3, 2412.25, 117.8, 1.0044
"670", 4.16, 1, 2411.82, -3.4, 1.0042, 2, 2478.52, -122.0, 1.032, 3, 2377.57, 117.1, 0.98992
"671", 4.16, 1, 2360.82, -5.4, 0.98295, 2, 2498.71, -122.4, 1.0404, 3, 2317.87, 116.0, 0.96506
"680", 4.16, 1, 2360.82, -5.4, 0.98295, 2, 2498.71, -122.4, 1.0404, 3, 2317.87, 116.0, 0.96506
"633", 4.16, 1, 2429.3, -2.6, 1.0115, 2, 2466.87, -121.8, 1.0271, 3, 2405.89, 117.8, 1.0017
"645", 4.16, 2, 2449.39, -121.9, 1.0198, 3, 2407.68, 117.8, 1.0025, 0, 0, 0, 0
"646", 4.16, 2, 2445.29, -122.0, 1.0181, 3, 2402.82, 117.9, 1.0004, 0, 0, 0, 0
"692", 4.16, 1, 2360.55, -5.4, 0.98283, 2, 2498.74, -122.4, 1.0404, 3, 2317.67, 116.0, 0.96498
"675", 4.16, 1, 2344.84, -5.6, 0.97629, 2, 2504.33, -122.6, 1.0427, 3, 2313, 116.0, 0.96304
"684", 4.16, 1, 2356.2, -5.4, 0.98102, 3, 2312.99, 115.9, 0.96303, 0, 0, 0, 0
"611", 4.16, 3, 2308.15, 115.8, 0.96102, 0, 0, 0, 0, 0, 0, 0, 0
"652", 4.16, 1, 2343.02, -5.3, 0.97554, 0, 0, 0, 0, 0, 0, 0, 0
"634", 0.48, 1, 273.615, -3.3, 0.98732, 2, 279.485, -122.3, 1.0085, 3, 272.312, 117.3, 0.98262
"650", 4.16, 1, 2401.78, 0.0, 1, 2, 2401.78, -120.0, 1, 3, 2401.78, 120.0, 1

```

## IEEE13BARRAS\_EXP\_SEQVOLTAGES - Notepad

File Edit Format View Help


```

Bus, V1, p.u., Base kV, V2, %V2/V1, V0, %V0/V1, Vresidual, %NEMA
"SOURCEBUS", 66395.3, 1, 115.00, 4.83483E-005, 7.282E-008, 4.31906E-006, 6.505E-009, 1.29572E-005, 4.916E-008
"REG", 2521.76, 1.05, 4.16, 14.9897, 0.5944, 14.9978, 0.5947, 44.9933, 0.5935
"632", 2440.08, 1.0159, 4.16, 12.1569, 0.4982, 25.0515, 1.027, 75.1544, 0.4928
"670", 2422.5, 1.0086, 4.16, 22.2863, 0.92, 44.0142, 1.817, 132.043, 0.8703
"671", 2391.91, 0.99589, 4.16, 42.1206, 1.761, 82.5513, 3.451, 247.654, 1.539
"680", 2391.91, 0.99589, 4.16, 42.1206, 1.761, 82.5513, 3.451, 247.654, 1.539
"633", 2433.98, 1.0134, 4.16, 12.1835, 0.5006, 25.9228, 1.065, 77.7685, 0.4945
"645", 0, 0, 4.16, 0, 0, 0, 0, 2419.21, 0
"646", 0, 0, 4.16, 0, 0, 0, 0, 2419.25, 0
"692", 2391.77, 0.99583, 4.16, 42.2223, 1.765, 82.6323, 3.455, 247.897, 1.543
"675", 2386.81, 0.99377, 4.16, 45.3923, 1.902, 87.8383, 3.68, 263.515, 1.654
"684", 0, 0, 4.16, 0, 0, 0, 0, 2289.4, 0
"611", 0, 0, 4.16, 0, 0, 0, 0, 2308.15, 0
"652", 0, 0, 4.16, 0, 0, 0, 0, 2343.02, 0
"634", 275.13, 0.99279, 0.48, 1.62814, 0.5918, 3.31856, 1.206, 9.95567, 0.514
"650", 2401.78, 1, 4.16, 0.000245058, 1.02E-005, 0.00018421, 7.67E-006, 0.000552629, 9.606E-006

```



# ARQUIVOS DE CORRENTE



The screenshot displays the OpenDSS software interface. A large blue arrow points to the 'Currents' menu item in the 'Show' dropdown. The 'Currents' submenu is open, showing options: 'Currents Seq', 'Currents Elem', and 'Currents Elem Resid'. The main window shows a circuit summary for 'MASTER\_RedeTeste13Barras.dss' with the following results:

```
Results for Actor ID# 1
CPU selected : 0
Status = SOLVED
Solution Mode = Snap
Number = 100
Load Mult = 1.000
Devices = 39
Buses = 16
Nodes = 41
Control Mode =STATIC
Total Iterations = 11
Control Iterations = 3
Max Sol Iter = 4

- Circuit Summary -

Year = 0
Hour = 0
Max pu. voltage = 1.0562
Min pu. voltage = 0.96102
Total Active Power: 3.56706 MW
Total Reactive Power: 1.73636 Mvar
Total Active Losses: 0.112108 MW, (3.143 %)
Total Reactive Losses: 0.327706 Mvar
Frequency = 60 Hz
Mode = Snap
Control Mode = STATIC
Load Model = PowerFlow
```

The status bar at the bottom indicates: Memory: 41536K, Circuit Status: SOLVED, Total Iterations = 11, Control Iterations = 3, Max Solution Iterations = 4.

SYMMETRICAL COMPONENT CURRENTS BY CIRCUIT ELEMENT (first 3 phases)

Element	Term	I1	I2	%I2/I1	I0	%I0/I1	%Normal	%Emergency
"VSOURCE.SOURCE"	1	19.917	2.5365	12.74	1.7771E-007	0.00	0.00	0.00
	2	19.917	2.5365	12.74	1.7771E-007	0.00	0.00	0.00
"LINE.650632"	1	523.74	64.187	12.26	47.984	9.16	147.93	98.62
	2	523.75	64.188	12.26	47.984	9.16	0.00	0.00
"LINE.632670"	1	392.18	105.06	26.79	72.778	18.56	120.48	80.32
	2	392.18	105.06	26.79	72.778	18.56	0.00	0.00
"LINE.670671"	1	360.83	106.28	29.46	73.441	20.35	118.45	78.96
	2	360.83	106.28	29.46	73.441	20.35	0.00	0.00
"LINE.671680"	1	0.0033011	0.00039731	12.04	5.4174E-005	1.64	0.00	0.00
	2	1.8088E-012	2.6929E-012	148.87	9.5869E-013	53.00	0.00	0.00
"LINE.632633"	1	69.117	6.2315	9.02	6.6284	9.59	20.47	13.65
	2	69.118	6.2315	9.02	6.6284	9.59	0.00	0.00
"LINE.632645"	1	64.382	0	0.00	0	0.00	16.10	10.73
	2	64.383	0	0.00	0	0.00	0.00	0.00
"LINE.645646"	1	64.383	0	0.00	0	0.00	16.10	10.73
	2	64.384	0	0.00	0	0.00	0.00	0.00
"LINE.692675"	1	120.25	45.158	37.55	67.917	56.48	51.71	34.47
	2	120.24	45.157	37.55	67.916	56.48	0.00	0.00
"LINE.671684"	1	62.71	0	0.00	0	0.00	15.68	10.45
	2	62.71	0	0.00	0	0.00	0.00	0.00
"LINE.684611"	1	71.158	0	0.00	0	0.00	17.79	11.86
	2	71.158	0	0.00	0	0.00	0.00	0.00
"LINE.684652"	1							
	2							
"CAPACITOR.CAP1"	1							
	2							
"CAPACITOR.CAP2"	1							
	2							
"TRANSFORMER.SUBESTACAO"	1							
	2							
"TRANSFORMER.XFM1"	1							

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault Vsource SOURCE Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.v

Warning: Duplicate new element definition: "Line.650632" Element def

Results for Actor ID # 1  
CPU selected: 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 4  
Control Mode = STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

- Circuit Summary -

Clear

// Files que descrevem o circuito

- Redirect subestacao.dss
- Redirect linecodes.dss
- Redirect lines.dss
- Redirect loadshape.dss
- Redirect loads.dss
- Redirect capacitor.dss
- Redirect transformer\_sub.dss
- Redirect transformer.dss
- Redirect regulators.dss
- Redirect switches.dss

Redirect tensao\_base.dss

solve

### Right-Click

- Do Selected (Ctrl+D)
- Save This Window
- Close Window
- Change to this Directory
- Open Selected File
- Edit Selected File
- Change Font...

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

IPelements Line 650632 Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.v

Warning: Duplicate new element definition: "Line.650632" Element def

Results for Actor ID # 1  
CPU selected: 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 4  
Control Mode = STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

- Circuit Summary -

Clear

// Files que descrevem o circuito

- Redirect subestacao.dss
- Redirect linecodes.dss
- Redirect lines.dss
- Redirect loadshape.dss
- Redirect loads.dss
- Redirect capacitor.dss
- Redirect transformer\_sub.dss
- Redirect transformer.dss
- Redirect regulators.dss
- Redirect switches.dss

Redirect wind\_power.dss

Redirect wind\_control.dss

Redirect pvssystemexample.dss

Redirect volt\_var\_pv.dss

Redirect storage\_power.dss

Redirect tensao\_base.dss

Main MASTER\_RedeTeste13Barras

Messages OpenDSS - C:\Users\HP\

Summary Results

Memory: 39600K Circuit Status: SOLVED Iterations = 4

LINE.650632

Property	Value
bus1	reg.1.2.3
bus2	632.1.2.3
linecode	601
length	2000
phases	3
r1	----
x1	----
r0	----
x0	----
C1	----
C0	----
rmatrix	16.562344E-005 12.953512E-005 6.391656E-005
ymatrix	10.000192786 19.500616E-005 0.000194553 18.1
cmatrix	10.00316483 10.001002609 0.002933989 10.000
Switch	False
Rg	0.01805
Xa	0.155081
rho	100
geometry	
units	ft
spacing	
wires	
EathModel	Deni
cncables	
tcables	
B1	----
B0	----
Seasons	1
Ratinqs	{400.1}
normamps	400
emrgamps	600
faultrate	0.1

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault Vsource SOURCE Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.v

Warning: Duplicate new element definition: "Line.650632" Element def

Results for Actor ID # 1

// Dados das linhas.

// Observação: Na barra 670 A @ colocado o equivalente da carga distribuída.

- New Line.650632 Phases=3 Bus1=Reg.1.2.3 Bus2=632.1.2.3 LineCode=601 Length=2000 units=ft
- New Line.632670 Phases=3 Bus1=632.1.2.3 Bus2=670.1.2.3 LineCode=601 Length=667 units=ft
- New Line.670671 Phases=3 Bus1=670.1.2.3 Bus2=671.1.2.3 LineCode=601 Length=1333 units=ft
- New Line.671680 Phases=3 Bus1=671.1.2.3 Bus2=680.1.2.3 LineCode=601 Length=1000 units=ft
- New Line.632633 Phases=3 Bus1=632.1.2.3 Bus2=633.1.2.3 LineCode=602 Length=500 units=ft
- New Line.632645 Phases=2 Bus1=632.3.2 Bus2=645.3.2 LineCode=603 Length=500 units=ft
- New Line.645646 Phases=2 Bus1=645.3.2 Bus2=646.3.2 LineCode=603 Length=300 units=ft
- New Line.692675 Phases=3 Bus1=692.1.2.3 Bus2=675.1.2.3 LineCode=606 Length=500 units=ft
- New Line.671684 Phases=2 Bus1=671.1.3 Bus2=684.1.3 LineCode=604 Length=300 units=ft
- New Line.684611 Phases=1 Bus1=684.3 Bus2=611.3 LineCode=605 Length=300 units=ft
- New Line.684652 Phases=1 Bus1=684.1 Bus2=652.1 LineCode=607 Length=800 units=ft

Main MASTER\_RedeTeste13Barras.dss lines.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\lines.dss

Circuit Status: SOLVED Total Iterations = 11, Control Iterations = 3, Max Solution

## CIRCUIT ELEMENT CURRENTS

(Currents into element from indicated bus)

## Power Delivery Elements

Bus	Phase	Magnitude, A	Angle	(Real)	+j	(Imag)
ELEMENT = "Vsource.SOURCE"						
SOURCEBUS	1	17.974	/_ 179.1 =	-17.971	+j	0.27999
SOURCEBUS	2	19.744	/_ 71.4 =	6.3102	+j	18.708
SOURCEBUS	3	22.283	/_ -58.4 =	11.661	+j	-18.988
-----						
SOURCEBUS	0	17.974	/_ -0.9 =	17.971	+j	-0.27999
SOURCEBUS	0	19.744	/_ -108.6 =	-6.3102	+j	-18.708
SOURCEBUS	0	22.283	/_ 121.6 =	-11.661	+j	18.988
ELEMENT = "Line.650632"						
REG	1	562.58	/_ -28.7 =	493.52	+j	-270.06
REG	2	418.99	/_ -141.3 =	-326.95	+j	-262.02
REG	3	591.73	/_ 93.4 =	-35.095	+j	590.69
-----						
632	1	562.59	/_ 151.3 =	-493.52	+j	270.07
632	2	418.99	/_ 38.7 =	326.95	+j	262.02
632	3	591.73	/_ -86.6 =	35.09	+j	-590.69
ELEMENT = "Line.632670"						
632	1	481.9	/_ -27.2 =	428.8	+j	-219.91
632	2	218.02	/_ -135.2 =	-154.74	+j	-153.58
632	3	480.26	/_ 99.6 =	-80.004	+j	473.55
-----						
670	1	481.91	/_ 152.8 =	-428.81	+j	219.91
670	2	218.02	/_ 44.8 =	154.75	+j	153.58
670	3	480.26	/_ -80.4 =	80.003	+j	-473.55

File Edit Format View Help

## CIRCUIT ELEMENT CURRENTS

(Currents into element from indicated bus)

## Power Delivery Elements

Bus	Phase	Magnitude, A	Angle	(Real)	+j	(Imag)
ELEMENT = "Vsource.SOURCE"						
SOURCEBUS	1	17.974 /_	179.1 =	-17.971	+j	0.27999
SOURCEBUS	2	19.744 /_	71.4 =	6.3102	+j	18.708
SOURCEBUS	3	22.283 /_	-58.4 =	11.661	+j	-18.988
-----						
SOURCEBUS	0	17.974 /_	-0.9 =	17.971	+j	-0.27999
SOURCEBUS	0	19.744 /_	-108.6 =	-6.3102	+j	-18.708
SOURCEBUS	0	22.283 /_	121.6 =	-11.661	+j	18.988
ELEMENT = "Line.650632"						
REG	1	562.58 /_	-28.7 =	493.52	+j	-270.06
REG	2	418.99 /_	-141.3 =	-326.95	+j	-262.02
REG	3	591.73 /_	93.4 =	-35.095	+j	590.69
REG	Resid	143.95 /_	-156.0 =	-131.48	+j	-58.604
-----						
632	1	562.59 /_	151.3 =	-493.52	+j	270.07
632	2	418.99 /_	38.7 =	326.95	+j	262.02
632	3	591.73 /_	-86.6 =	35.09	+j	-590.69
632	Resid	143.95 /_	24.0 =	131.48	+j	58.605
ELEMENT = "Line.632670"						
632	1	481.9 /_	-27.2 =	428.8	+j	-219.91
632	2	218.02 /_	-135.2 =	-154.74	+j	-153.58
632	3	480.26 /_	99.6 =	-80.004	+j	473.55
632	Resid	218.33 /_	-152.7 =	-194.06	+j	-100.06
-----						
670	1	481.91 /_	152.8 =	-428.81	+j	219.91

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Make Export Show Visualize Plot Reset Help

C:\Users\HP\Desktop\openDSS\

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 41  
Control Mode =STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

- Circuit Summary -

Line 650632  
MASTER\_RedeTeste13Barras

Base Frequency = 60 Hz

Result  
Voltages  
Currents  
Powers  
Losses  
Summary  
Buscoords  
Fault Currents  
Capacity  
Overloads  
Unservd  
Generators  
Loads  
Node Names  
Node Order  
Meters  
Estimation  
Monitors ...  
Yprims  
Y  
Seq Z

Terminal  
Sequence  
Element

ss  
s  
s  
s  
ub.dss  
ss  
s  
dss

Main MASTER\_RedeTeste13Barras.dss lines.dss

Messages Main

Summary Results

Memory: 40024K Circuit Status: SOLVED Total Iterations = 11, Control Iterations = 3, Max Solution Iterations = 4

Clipboard: Paste, Copy, Cut

Font: Calibri, 11, Bold, Italic, Underline, Text Color, Background Color, Font Color, Paragraph Spacing, Bullets, Numbering, Merge & Center, Wrap Text

Alignment: General, Text, Center, Right, Left, Indent, Decrease Indent, Increase Indent, Merge & Center, Wrap Text

Number: General, Text, Percentage, Comma, Thousands Separator, Negative numbers in parentheses, Negative numbers with leading minus sign, Fractions, Decimals, Scientific notation, Custom number format

Styles: Conditional Formatting, Format as Table, Cell Styles

Cells: Insert, Delete, Format

Editing: AutoSum, Fill, Clear, Sort & Filter, Find & Select

A1 Element

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
1	Element	I1_1	Ang1_1	I1_2	Ang1_2	I1_3	Ang1_3	I1_4	Ang1_4	Iresid1	AngResid	I2_1	Ang2_1	I2_2	Ang2_2	I2_3	Ang2_3	I2_4	Ang2_4	Iresid2	AngR
2	Vsource.S	17.9736	179.11	19.7436	71.36	22.2829	-58.44	0	0	5.33E-07	-153.43	17.9736	-0.89	19.7436	-108.64	22.2829	121.56	0	0	5.33E-07	2
3	Line.6506	562.582	-28.69	418.987	-141.29	591.729	93.4	0	0	143.951	24.02	562.586	151.31	418.988	38.71	591.732	-86.6	0	0	143.951	-15
4	Line.6326	481.905	-27.15	218.022	-135.22	480.258	99.59	0	0	218.333	27.28	481.906	152.85	218.022	44.78	480.259	-80.41	0	0	218.334	-15
5	Line.6706	473.786	-27.03	188.794	-132.54	424.898	101.27	0	0	220.322	16.41	473.788	152.97	188.794	47.46	424.899	-78.73	0	0	220.322	-16
6	Line.6716	0.003553	90.6	0.003436	-41.05	0.002958	-150.47	0	0	0.000163	-97.11	4.55E-13	0	4.19E-12	12.53	4.07E-12	153.43	0	0	2.88E-12	7
7	Line.6326	81.8831	-37.78	61.9247	-159.13	63.5634	80.41	0	0	19.8853	-28.69	81.884	142.22	61.9255	20.87	63.5645	-99.59	0	0	19.8852	15
8	Line.6326	64.3823	57.78	143.303	-142.93	0	0	0	0	86.1464	-158.26	64.3832	-122.22	143.304	37.07	0	0	0	0	86.1461	2
9	Line.6456	64.3832	57.78	64.3836	-122.22	0	0	0	0	0.000521	-91.79	64.3838	-122.22	64.3838	57.78	0	0	0	0	3.28E-12	-3
10	Line.6926	206.848	-5.54	68.5035	-55.9	125.917	110.79	0	0	203.751	11.61	206.848	174.45	68.4824	124.09	125.919	-69.22	0	0	203.748	-16
11	Line.6716	62.7098	-39.19	71.1576	121.18	0	0	0	0	24.29	61.04	62.7101	140.81	71.1576	-58.82	0	0	0	0	24.29	-11
12	Line.6846	71.1576	121.18	0	0	0	0	0	0	71.1576	121.18	71.1576	-58.82	0	0	0	0	0	0	71.1576	-5
13	Line.6846	62.7101	-39.19	0	0	0	0	0	0	62.7101	-39.19	62.7278	140.79	0	0	0	0	0	0	62.7278	14
14	Capacitor.	81.2975	84.38	86.8274	-32.55	80.1937	-153.99	0	0	9.13629	-6.18	81.2975	-95.62	86.8274	147.45	80.1937	26.01	0	0	9.13629	17
15	Capacitor.	40.0721	-154.25	0	0	0	0	0	0	40.0721	-154.25	40.0721	25.75	0	0	0	0	0	0	40.0721	2
16	Transform	17.9736	-0.89	19.7435	-108.64	22.2829	121.56	0	0	3.73E-09	-90	594.228	151.31	434.699	38.71	625.014	-86.6	159.66	24.74	1.20E-07	2
17	Transform	81.884	-37.78	61.9255	-159.13	63.5645	80.41	19.8852	151.31	1.12E-06	-175.57	709.661	142.22	536.687	20.87	550.892	-99.59	172.339	-28.69	1.08E-05	17
18	Transform	594.228	-28.69	594.228	151.31	0	0	0	0	0.000347	-90	562.582	151.31	562.582	-28.69	0	0	0	0	0.000367	
19	Transform	434.699	-141.29	434.699	38.71	0	0	0	0	0.000347	150	418.987	38.71	418.987	-141.29	0	0	0	0	0.000361	
20	Transform	625.014	93.4	625.014	-86.6	0	0	0	0	0.000347	30	591.729	-86.6	591.729	93.4	0	0	0	0	0.000367	
21	Line.6716	230.948	-18.43	68.5035	-55.9	180.309	108.74	0	0	203.751	11.61	230.948	161.57	68.5035	124.1	180.309	-71.26	0	0	203.751	-16
22	Load.671	185.361	-33.65	185.359	-153.62	185.447	86.37	0	0	2.13E-14	0	0	0	0	0	0	0	0	0	0	
23	Load.6344	709.645	-37.78	709.645	142.22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

Clipboard Font Alignment Number Styles Cells Editing

Calibri 11 A A Wrap Text Merge & Center General \$ % , .00 .00 Conditional Formatting Format as Table Cell Styles Insert Delete Format AutoSum Fill Clear Sort & Filter Find & Select

A1 Element

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
1	Element	Terminal	I1	%Normal	%Emerge	I2	%I2/I1	I0	%I0/I1	Iresidual	%NEMA										
2	Vsource.S	1	19.9172	0	0	2.53647	12.74	1.78E-07	8.92E-07	5.33E-07	11.41										
3	Vsource.S	2	19.9172	0	0	2.53647	12.74	1.78E-07	8.92E-07	5.33E-07	11.41										
4	Line.65063	1	523.744	130.9	87.29	64.1873	12.26	47.9836	9.162	143.951	20.11										
5	Line.65063	2	523.747	0	0	64.1879	12.26	47.9837	9.162	143.951	20.11										
6	Line.63267	1	392.178	98.04	65.36	105.059	26.79	72.7778	18.56	218.333	44.58										
7	Line.63267	2	392.179	0	0	105.059	26.79	72.7779	18.56	218.333	44.58										
8	Line.67067	1	360.826	90.21	60.14	106.283	29.46	73.4406	20.35	220.322	47.92										
9	Line.67067	2	360.827	0	0	106.283	29.46	73.4407	20.35	220.322	47.92										
10	Line.67168	1	0.003301	0.000825	0.00055	0.000397	12.04	5.42E-05	1.641	0.000163	10.78										
11	Line.67168	2	1.81E-12	0	0	2.69E-12	148.9	9.59E-13	53	0.000163	84.35										
12	Line.63263	1	69.1171	17.28	11.52	6.23152	9.016	6.62845	9.59	19.8853	18.46										
13	Line.63263	2	69.118	0	0	6.23152	9.016	6.62841	9.59	19.8853	18.46										
14	Line.63264	1	0	0	0	0	0	0	0	86.1464	0										
15	Line.63264	2	0	0	0	0	0	0	0	86.1464	0										
16	Line.64564	1	0	0	0	0	0	0	0	0.000521	0										
17	Line.64564	2	0	0	0	0	0	0	0	0.000521	0										
18	Line.69267	1	120.247	30.06	20.04	45.1576	37.55	67.9169	56.48	203.751	54.65										
19	Line.69267	2	120.244	0	0	45.1574	37.55	67.9161	56.48	203.751	54.65										
20	Line.67168	1	0	0	0	0	0	0	0	24.29	0										
21	Line.67168	2	0	0	0	0	0	0	0	24.29	0										
22	Line.68467	1	0	0	0	0	0	0	0	71.1576	0										
23	Line.68467	2	0	0	0	0	0	0	0	71.1576	0										

Clipboard Font Alignment Number Styles Cells Editing


Calibri 11 A A Wrap Text Merge & Center \$ % 0.00 0.00

Conditional Formatting Table Cell Styles Insert Delete Format AutoSum Fill Clear Sort & Filter Find & Select

A1 Element

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
1	Element	Ntermina	Nconduct	I_1	Ang_1	...															
2	Vsource.s	2	3	17.9736	179.11	19.7436	71.36	22.2829	-58.44	17.9736	-0.89	19.7436	-108.64	22.2829	121.56						
3	Line.65063	2	3	562.582	-28.69	418.987	-141.29	591.729	93.4	562.586	151.31	418.988	38.71	591.732	-86.6						
4	Line.63267	2	3	481.905	-27.15	218.022	-135.22	480.258	99.59	481.906	152.85	218.022	44.78	480.259	-80.41						
5	Line.67067	2	3	473.786	-27.03	188.794	-132.54	424.898	101.27	473.788	152.97	188.794	47.46	424.899	-78.73						
6	Line.67168	2	3	0.003553	90.6	0.003436	-41.05	0.002958	-150.47	4.55E-13	0	4.19E-12	12.53	4.07E-12	153.43						
7	Line.63263	2	3	81.8831	-37.78	61.9247	-159.13	63.5634	80.41	81.884	142.22	61.9255	20.87	63.5645	-99.59						
8	Line.63264	2	2	64.3823	57.78	143.303	-142.93	64.3832	-122.22	143.304	37.07										
9	Line.64564	2	2	64.3832	57.78	64.3836	-122.22	64.3838	-122.22	64.3838	57.78										
10	Line.69267	2	3	206.848	-5.54	68.5035	-55.9	125.917	110.79	206.848	174.45	68.4824	124.09	125.919	-69.22						
11	Line.67168	2	2	62.7098	-39.19	71.1576	121.18	62.7101	140.81	71.1576	-58.82										
12	Line.68463	2	1	71.1576	121.18	71.1576	-58.82														
13	Line.68463	2	1	62.7101	-39.19	62.7278	140.79														
14	Capacitor.	2	3	81.2975	84.38	86.8274	-32.55	80.1937	-153.99	81.2975	-95.62	86.8274	147.45	80.1937	26.01						
15	Capacitor.	2	1	40.0721	-154.25	40.0721	25.75														
16	Transform	2	4	17.9736	-0.89	19.7435	-108.64	22.2829	121.56	0	0	594.228	151.31	434.699	38.71	625.014	-86.6	159.66	24.74		
17	Transform	2	4	81.884	-37.78	61.9255	-159.13	63.5645	80.41	19.8852	151.31	709.661	142.22	536.687	20.87	550.892	-99.59	172.339	-28.69		
18	Transform	2	2	594.228	-28.69	594.228	151.31	562.582	151.31	562.582	-28.69										
19	Transform	2	2	434.699	-141.29	434.699	38.71	418.987	38.71	418.987	-141.29										
20	Transform	2	2	625.014	93.4	625.014	-86.6	591.729	-86.6	591.729	93.4										
21	Line.67169	2	3	230.948	-18.43	68.5035	-55.9	180.309	108.74	230.948	161.57	68.5035	124.1	180.309	-71.26						
22	Load.671	1	3	185.361	-33.65	185.359	-153.62	185.447	86.37												
23	Load.634a	1	2	709.645	-37.78	709.645	142.22														

# ARQUIVOS DE POTÊNCIA



The screenshot displays the OpenDSS software interface. The title bar indicates the data directory: "OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\". The main window shows a menu structure with "Powers" selected, revealing sub-options: "Powers kVA", "Powers MVA", "Powers kVA Elem", and "Powers MVA Elem". A blue arrow points to the "Powers" menu item. The left sidebar contains a "Results for Actor ID # 1" section with the following details:

- CPU selected : 0
- Status = SOLVED
- Solution Mode = Snap
- Number = 100
- Load Mult = 1.000
- Devices = 39
- Buses = 16
- Nodes = 41
- Control Mode = STATIC
- Total Iterations = 11
- Control Iterations = 3
- Max Sol Iter = 4

The bottom status bar shows: "Memory: 39172K", "Circuit Status: SOLVED", and "Total Iterations = 11, Control Iterations = 3, Max Solution Iterations = 4".

## SYMMETRICAL COMPONENT POWERS BY CIRCUIT ELEMENT (first 3 phases)

## Excess Power

Element	Term	P1(kW)	Q1(kvar)	P2	Q2	P0	Q0	P_Norm	Q_Norm	P_Emerg	Q_Emerg
"Vsource.SOURCE"	1	-3567.1	-1736.4	-0.0	0.0	-0.0	-0.0				
"Vsource.SOURCE"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.650632"	1	3563.4	1732.6	1.9	2.2	1.7	1.3	1155.8	562.5	0.0	0.0
"Line.650632"	2	-3508.7	-1545.5	1.3	1.9	1.0	3.5				
"Line.632670"	1	2697.0	983.9	-3.1	-2.3	-1.9	-5.1	457.5	166.0	0.0	0.0
"Line.632670"	2	-2687.6	-948.9	4.9	5.0	3.6	8.9				
"Line.670671"	1	2486.5	832.9	-5.6	-4.4	-1.9	-9.5	386.1	127.5	0.0	0.0
"Line.670671"	2	-2470.8	-773.9	9.1	9.8	5.4	17.4				
"Line.671680"	1	-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.671680"	2	0.0	-0.0	-0.0	-0.0	-0.0	-0.0				
"Line.632633"	1	406.3	301.5	-0.2	0.1	0.3	-0.4	0.0	0.0	0.0	0.0
"Line.632633"	2	-405.5	-300.5	0.2	-0.1	-0.3	0.4				
"Line.632645"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.632645"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.645646"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.645646"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.692675"	1	855.8	-109.7	-4.9	-2.9	-3.6	-16.4	0.0	0.0	0.0	0.0
"Line.692675"	2	-853.8	111.3	5.3	3.2	5.5	17.0				
"Line.671684"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.671684"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.684611"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.684611"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.684652"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.684652"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Capacitor.CAP1"	1	-0.0	-592.5	0.0	-0.2	-0.0	-0.8	0.0	0.0	0.0	0.0
"Capacitor.CAP1"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Capacitor.CAP2"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Capacitor.CAP2"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Transformer.SUBESTACAO"	1	3567.1	1736.4	0.0	-0.0	-0.0	0.0	0.0	0.0	0.0	0.0
"Transformer.SUBESTACAO"	2	-3567.1	-1736.4	0.0	0.0	0.0	0.0				
"Transformer.XFM1"	1	405.5	300.5	-0.2	0.1	0.3	-0.4	27.5	20.3	0.0	0.0

## SYMMETRICAL COMPONENT POWERS BY CIRCUIT ELEMENT (first 3 phases)

## Excess Power

Element	Term	P1(MW)	Q1(Mvar)	P2	Q2	P0	Q0	P_Norm	Q_Norm	P_Emerg	Q_Emerg
"Vsource.SOURCE"	1	-3.6	-1.7	-0.0	0.0	-0.0	-0.0				
"Vsource.SOURCE"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.650632"	1	3.6	1.7	0.0	0.0	0.0	0.0	1.2	0.6	0.0	0.0
"Line.650632"	2	-3.5	-1.5	0.0	0.0	0.0	0.0				
"Line.632670"	1	2.7	1.0	-0.0	-0.0	-0.0	-0.0	0.5	0.2	0.0	0.0
"Line.632670"	2	-2.7	-0.9	0.0	0.0	0.0	0.0				
"Line.670671"	1	2.5	0.8	-0.0	-0.0	-0.0	-0.0	0.4	0.1	0.0	0.0
"Line.670671"	2	-2.5	-0.8	0.0	0.0	0.0	0.0				
"Line.671680"	1	-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.671680"	2	0.0	-0.0	-0.0	-0.0	-0.0	-0.0				
"Line.632633"	1	0.4	0.3	-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0
"Line.632633"	2	-0.4	-0.3	0.0	-0.0	-0.0	0.0				
"Line.632645"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.632645"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.645646"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.645646"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.692675"	1	0.9	-0.1	-0.0	-0.0	-0.0	-0.0	0.0	0.0	0.0	0.0
"Line.692675"	2	-0.9	0.1	0.0	0.0	0.0	0.0				
"Line.671684"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.671684"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.684611"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.684611"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Line.684652"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Line.684652"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Capacitor.CAP1"	1	-0.0	-0.6	0.0	-0.0	-0.0	-0.0	0.0	0.0	0.0	0.0
"Capacitor.CAP1"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Capacitor.CAP2"	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
"Capacitor.CAP2"	2	0.0	0.0	0.0	0.0	0.0	0.0				
"Transformer.SUBESTACAO"	1	3.6	1.7	0.0	-0.0	-0.0	0.0	0.0	0.0	0.0	0.0
"Transformer.SUBESTACAO"	2	-3.6	-1.7	0.0	0.0	0.0	0.0				
"Transformer.XFM1"	1	0.4	0.3	-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0

File Edit Format View Help

## CIRCUIT ELEMENT POWER FLOW

(Power Flow into element from indicated Bus)

## Power Delivery Elements

Bus	Phase	kW	+j	kvar	kVA	PF
ELEMENT = "Vsource.SOURCE"						
SOURCEBUS	1	-1024.1	+j	-612.7	1193.4	0.8581
SOURCEBUS	2	-1242.1	+j	-419.0	1310.9	0.9475
SOURCEBUS	3	-1300.9	+j	-704.7	1479.5	0.8793
TERMINAL TOTAL .		-3567.1	+j	-1736.4	3967.2	0.8991
SOURCEBUS	0	0.0	+j	0.0	0.0	1.0000
SOURCEBUS	0	0.0	+j	0.0	0.0	1.0000
SOURCEBUS	0	0.0	+j	0.0	0.0	1.0000
TERMINAL TOTAL .		0.0	+j	0.0	0.0	1.0000
ELEMENT = "Line.650632"						
REG	1	1252.0	+j	685.0	1427.1	0.8773
REG	2	972.8	+j	379.0	1044.0	0.9318
REG	3	1342.2	+j	672.0	1501.1	0.8942
TERMINAL TOTAL .		3567.0	+j	1736.0	3967.0	0.8992
632	1	-1230.3	+j	-604.5	1370.8	0.8975
632	2	-975.9	+j	-346.4	1035.5	0.9424
632	3	-1300.1	+j	-589.2	1427.4	0.9108
TERMINAL TOTAL .		-3506.3	+j	-1540.1	3829.6	0.9156
ELEMENT = "Line.632670"						
632	1	1067.4	+j	489.4	1174.2	0.9090
632	2	524.0	+j	125.5	538.8	0.9725
632	3	1100.6	+j	361.6	1158.5	0.9500
TERMINAL TOTAL .		2692.0	+j	976.5	2863.6	0.9401
670	1	-1064.2	+j	-467.2	1162.3	0.9156
670	2	-526.0	+j	-123.9	540.4	0.9734

File Edit Format View Help

## CIRCUIT ELEMENT POWER FLOW

(Power Flow into element from indicated Bus)

## Power Delivery Elements

Bus	Phase	MW	+j	Mvar	MVA	PF
ELEMENT = "Vsource.SOURCE"						
SOURCEBUS	1	-1.0	+j	-0.6	1.2	0.8581
SOURCEBUS	2	-1.2	+j	-0.4	1.3	0.9475
SOURCEBUS	3	-1.3	+j	-0.7	1.5	0.8793
TERMINAL TOTAL .		-3.6	+j	-1.7	4.0	0.8991
SOURCEBUS	0	0.0	+j	0.0	0.0	1.0000
SOURCEBUS	0	0.0	+j	0.0	0.0	1.0000
SOURCEBUS	0	0.0	+j	0.0	0.0	1.0000
TERMINAL TOTAL .		0.0	+j	0.0	0.0	1.0000
ELEMENT = "Line.650632"						
REG	1	1.3	+j	0.7	1.4	0.8773
REG	2	1.0	+j	0.4	1.0	0.9318
REG	3	1.3	+j	0.7	1.5	0.8942
TERMINAL TOTAL .		3.6	+j	1.7	4.0	0.8992
632	1	-1.2	+j	-0.6	1.4	0.8975
632	2	-1.0	+j	-0.3	1.0	0.9424
632	3	-1.3	+j	-0.6	1.4	0.9108
TERMINAL TOTAL .		-3.5	+j	-1.5	3.8	0.9156
ELEMENT = "Line.632670"						
632	1	1.1	+j	0.5	1.2	0.9090
632	2	0.5	+j	0.1	0.5	0.9725
632	3	1.1	+j	0.4	1.2	0.9500
TERMINAL TOTAL .		2.7	+j	1.0	2.9	0.9401
670	1	-1.1	+j	-0.5	1.2	0.9156
670	2	-0.5	+j	-0.1	0.5	0.9734

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit View Options Help

Export Show Visualize Plot Reset Help

Line 650632 C V P Base Frequency = 60 Hz

MASTER\_RedeTeste13Barras

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 41  
Control Mode =STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

- Circuit Summary -

- Result
- Voltages
- Currents
- Powers
  - Terminal
  - By Phase
  - Sequence
  - Element
- Losses
- Summary
- Buscoords
- Fault Currents
- Capacity
- Overloads
- Unservd
- Generators
- Loads
- Node Names
- Node Order
- Meters
- Estimation
- Monitors ...
- Yprims
- Y
- Seq Z

Main MASTER\_RedeTeste13Barras.dss lines.dss

Messages Main

Summary Results

Memory: 39184K Circuit Status: SOLVED Total Iterations = 11, Control Iterations = 3, Max Solution Iterations = 4

IEEE13BARRAS\_EXP\_POWERS - Excel

seyed iman taheri

File Home Insert Page Layout Formulas Data Review View Help Tell me what you want to do

Clipboard Font Alignment Number Styles Cells Editing

Calibri 11 A A Wrap Text Merge & Center General \$ % , .00 .00 Conditional Formatting Format as Table Cell Styles Insert Delete Format AutoSum Fill Clear Sort & Filter Find & Select

A1 Element

Element	Terminal	P(kW)	Q(kvar)	P_Norma	Q_Norma	P_Emerge	Q_Emergency
Line.6506	1	3567	1736	1155.8	562.5	0	0
Line.6506	2	-3506.3	-1540.1				
Line.6326	1	2692	976.5	457.5	166	0	0
Line.6326	2	-2679	-935				
Line.6706	1	2479	819	386.1	127.5	0	0
Line.6706	2	-2456.3	-746.7				
Line.6716	1	0	0	0	0	0	0
Line.6716	2	0	0				
Line.6326	1	406.4	301.2	0	0	0	0
Line.6326	2	-405.6	-300.1				
Line.6326	1	407.9	262.5	0	0	0	0
Line.6326	2	-405.1	-260.1				
Line.6456	1	235.1	135.1	0	0	0	0
Line.6456	2	-234.6	-134.7				
Line.6926	1	847.2	-129	0	0	0	0
Line.6926	2	-843.1	131.5				
Line.6716	1	287.3	67.5	0	0	0	0
Line.6716	2	-286.7	-67				
Line.6846	1	163.9	-15.2	0	0	0	0
Line.6846	2	-163.5	15.5				
Line.6846	1	122.8	82.2	0	0	0	0
Line.6846	2	-122	-82				

IEEE13BARRAS\_EXP\_POWERS

Ready 100%

Clipboard Font Alignment Number Styles Cells Editing

Calibri 11 Wrap Text Merge & Center

Conditional Formatting Format as Table Cell Styles

AutoSum Fill Clear Sort & Find & Filter Select

A1 Element

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
1	Element	NumTerm	NumConc	NumPhas	kW1	kvar1	kW2	kvar2	kW3	kvar3	...										
2	Line.6506	2	3	3	1251.997	684.989	972.788	379.027	1342.242	672.01	-1230.3	-604.532	-975.876	-346.388	-1300.14	-589.165					
3	Line.6326	2	3	3	1067.382	489.359	524.025	125.485	1100.617	361.613	-1064.22	-467.24	-525.978	-123.89	-1088.84	-343.852					
4	Line.6706	2	3	3	1047.218	457.24	459.98	85.891	971.833	275.846	-1039.48	-413.027	-464.343	-83.221	-952.488	-250.43					
5	Line.6716	2	3	3	-0.001	-0.008	0.001	-0.008	0	-0.007	0	0	0	0	0	0					
6	Line.6326	2	3	3	162.918	115.173	121.61	92.921	121.863	93.058	-162.56	-114.647	-121.457	-92.652	-121.55	-92.806					
7	Line.6326	2	2	2	77.66	134.495	330.242	127.982	-77.448	-134.28	-327.694	-125.785									
8	Line.6456	2	2	2	77.448	134.28	157.699	0.788	-77.184	-134.073	-157.436	-0.578									
9	Line.6926	2	3	3	488.272	1.499	68.313	-156.95	290.631	26.462	-485.024	0.619	-67.997	157.447	-290.039	-26.541					
10	Line.6716	2	2	2	122.993	82.406	164.259	-14.904	-122.785	-82.196	-163.887	15.162									
11	Line.6846	2	1	1	163.887	-15.162	-163.505	15.549													
12	Line.6846	2	1	1	122.785	82.196	-121.994	-81.965													
13	Capacitor.	2	3	3	0	-190.629	0	-217.445	0	-185.488	0	0	0	0	0	0					
14	Capacitor.	2	1	1	0	-92.492	0	0													
15	Transform	2	4	3	1024.062	612.708	1242.122	418.969	1300.875	704.684	0	0	-1252.01	-685.112	-972.794	-379.094	-1342.26	-672.147	0	0	
16	Transform	2	4	3	162.56	114.647	121.457	92.652	121.55	92.806	0	0	-160.007	-110.005	-119.997	-89.998	-120.011	-90.009	0	0	
17	Transform	2	2	1	1252.009	685.112	0	0	-1252	-684.989	0	0									
18	Transform	2	2	1	972.794	379.094	0	0	-972.788	-379.027	0	0									
19	Transform	2	2	1	1342.256	672.147	0	0	-1342.24	-672.01	0	0									
20	Line.6716	2	3	3	531.108	123.281	68.318	-156.945	414.58	52.834	-531.055	-123.228	-68.313	156.95	-414.548	-52.801					
21	Load.671	1	3	3	385.366	207.345	396.017	240.179	373.631	212.515											
22	Load.634A	1	2	1	160	110.007	0	0													
23	Load.634B	1	2	1	119.999	89.998	0	0													

Clipboard Font Alignment Number Styles Cells Editing

Calibri 11 A A Wrap Text General

B I U Merge & Center \$ % .0 .00 Conditional Formatting Format as Table Cell Styles Insert Delete Format AutoSum Fill Clear Sort & Filter Find & Select

A1 Element

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
1	Element	Terminal	P1(kW)	Q1(kvar)	P2	Q2	P0	Q0	P_Norma	Q_Norma	P_Emerge	Q_Emergency									
2	Line.6506	1	3563.4	1732.6	1.9	2.2	1.7	1.3	1155.8	562.5	0	0									
3	Line.6506	2	-3508.7	-1545.5	1.3	1.9	1	3.5													
4	Line.6326	1	2697	983.9	-3.1	-2.3	-1.9	-5.1	457.5	166	0	0									
5	Line.6326	2	-2687.6	-948.9	4.9	5	3.6	8.9													
6	Line.6706	1	2486.5	832.9	-5.6	-4.4	-1.9	-9.5	386.1	127.5	0	0									
7	Line.6706	2	-2470.8	-773.9	9.1	9.8	5.4	17.4													
8	Line.6716	1	0	0	0	0	0	0	0	0	0	0									
9	Line.6716	2	0	0	0	0	0	0	0	0	0	0									
10	Line.6326	1	406.3	301.5	-0.2	0.1	0.3	-0.4	0	0	0	0									
11	Line.6326	2	-405.5	-300.5	0.2	-0.1	-0.3	0.4													
12	Line.6326	1	0	0	0	0	0	0	0	0	0	0									
13	Line.6326	2	0	0	0	0	0	0													
14	Line.6456	1	0	0	0	0	0	0	0	0	0	0									
15	Line.6456	2	0	0	0	0	0	0													
16	Line.6926	1	855.8	-109.7	-4.9	-2.9	-3.6	-16.4	0	0	0	0									
17	Line.6926	2	-853.8	111.3	5.3	3.2	5.5	17													
18	Line.6716	1	0	0	0	0	0	0	0	0	0	0									
19	Line.6716	2	0	0	0	0	0	0	0	0	0	0									
20	Line.6846	1	0	0	0	0	0	0	0	0	0	0									
21	Line.6846	2	0	0	0	0	0	0	0	0	0	0									
22	Line.6846	1	0	0	0	0	0	0	0	0	0	0									
23	Line.6846	2	0	0	0	0	0	0	0	0	0	0									

IEEE13BARRAS\_EXP\_SEQPOWERS

Clipboard: Paste, Copy, Cut

Font: Calibri, 11, Bold, Italic, Underline, Text Color, Background Color

Alignment: Center, Left, Right, Indent, Wrap Text, Merge & Center

Number: General, Currency, Percentage, Decimals

Styles: Conditional Formatting, Format as Table, Cell Styles


Cells: Insert, Delete, Format

Editing: AutoSum, Fill, Clear, Sort & Filter, Find & Select

A1 Element

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U
1	Element	Ntermina	Nconduct	P_1	Q_1	...															
2	Vsource.s	2	3	-1024.06	-612.708	-1242.12	-418.969	-1300.88	-704.685	0	0	0	0	0	0						
3	Line.6506	2	3	1252	684.989	972.788	379.027	1342.24	672.01	-1230.3	-604.532	-975.876	-346.388	-1300.14	-589.165						
4	Line.6326	2	3	1067.38	489.359	524.025	125.485	1100.62	361.613	-1064.22	-467.24	-525.978	-123.89	-1088.84	-343.852						
5	Line.6706	2	3	1047.22	457.24	459.98	85.8911	971.833	275.846	-1039.48	-413.027	-464.343	-83.2211	-952.488	-250.43						
6	Line.6716	2	3	-0.00087	-0.00834	0.001294	-0.00849	-0.00042	-0.00684	1.07E-12	-1.00E-13	-7.40E-12	-7.42E-12	7.49E-12	-5.73E-12						
7	Line.6326	2	3	162.918	115.173	121.61	92.9209	121.863	93.0576	-162.56	-114.647	-121.457	-92.6523	-121.55	-92.8058						
8	Line.6326	2	2	77.6598	134.495	330.242	127.982	-77.4483	-134.28	-327.694	-125.785										
9	Line.6456	2	2	77.4483	134.28	157.699	0.787801	-77.1835	-134.073	-157.436	-0.57811										
10	Line.6926	2	3	488.272	1.49902	68.3134	-156.95	290.631	26.462	-485.024	0.618705	-67.9973	157.447	-290.039	-26.5412						
11	Line.6716	2	2	122.993	82.4055	164.259	-14.9037	-122.785	-82.196	-163.887	15.1624										
12	Line.6846	2	1	163.887	-15.1624	-163.505	15.5487														
13	Line.6846	2	1	122.785	82.196	-121.994	-81.9651														
14	Capacitor.	2	3	0	-190.629	1.46E-14	-217.445	-1.46E-14	-185.488	0	0	0	0	0	0						
15	Capacitor.	2	1	0	-92.4923	0	0														
16	Transform	2	4	1024.06	612.708	1242.12	418.969	1300.88	704.684	0	0	-1252.01	-685.112	-972.794	-379.094	-1342.26	-672.147	0	0		
17	Transform	2	4	162.56	114.647	121.457	92.6523	121.55	92.8058	0	0	-160.007	-110.005	-119.997	-89.9977	-120.011	-90.0087	0	0		
18	Transform	2	2	1252.01	685.112	0	0	-1252	-684.989	0	0										
19	Transform	2	2	972.794	379.094	0	0	-972.788	-379.027	0	0										
20	Transform	2	2	1342.26	672.147	0	0	-1342.24	-672.01	0	0										
21	Line.6716	2	3	531.108	123.281	68.3181	-156.945	414.58	52.8336	-531.055	-123.228	-68.3134	156.95	-414.548	-52.8011						
22	Load.671	1	3	385.366	207.345	396.017	240.179	373.631	212.515												
23	Load.634a	1	2	160	110.007	0	0														

# PERFIL DE TENSÃO



The screenshot displays the OpenDSS software interface. The main window title is "OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\". The menu bar includes "File", "Edit", "Do", "Plot", "Reset", and "Help". The "Plot" menu is open, showing options: "Circuit Plots", "Monitor", "Loadshapes", "Profile", "TCC Curves", "Interpolate", and "Options...". The "Profile" option is highlighted with a blue arrow. A large blue arrow points from the left towards the "Plot" menu. The main workspace is yellow and contains the following text:

```
Clear
//-----//
// Files que descrevem o sistema -----//
Redirect subestacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitors.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss

Redirect tensao_base.dss

solve
```

The left sidebar shows "Results for Actor ID # 1" with the following details:


- CPU selected : 0
- Status = SOLVED
- Solution Mode = Snap
- Number = 100
- Load Mult = 1.000
- Devices = 39
- Buses = 16
- Nodes = 41
- Control Mode = STATIC
- Total Iterations = 11
- Control Iterations = 3
- Max Sol Iter = 4


The bottom status bar shows: "Memory: 33260K", "Circuit Status: SOLVED", and "Total Iterations = 11, Control Iterations = 3, Max Solution Iterations = 4".

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 41  
Control Mode =STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

Clear  
//-----  
// Files que descrevem o  
Redirect subestacao.dss  
Redirect linecodes.dss  
Redirect lines.dss  
Redirect loadshape.dss  
Redirect loads.dss  
Redirect capacitors.dss  
Redirect transformer\_sub  
Redirect transformer.dss  
Redirect regulators.dss  
Redirect switches.dss

Redirect tensao\_base.dss  
solve







IEEE13BARRAS\_VLN\_elem - Notepad

```


File Edit Format View Help
SOURCEBUS ( 0) 0 0 ( 0) /_ 0.0
SOURCEBUS ( 0) 0 0 ( 0) /_ 0.0
SOURCEBUS ( 0) 0 0 ( 0) /_ 0.0

ELEMENT = "Line.650632"
REG ( 4) 1 2.5368 ( 1.056) /_ 0.0
REG ( 5) 2 2.4918 ( 1.037) /_ -120.0
REG ( 6) 3 2.5368 ( 1.056) /_ 120.0
-----
632 ( 7) 1 2.4366 ( 1.015) /_ -2.5
632 ( 8) 2 2.4715 ( 1.029) /_ -121.7
632 ( 9) 3 2.4122 ( 1.004) /_ 117.8
-----
ELEMENT = "Line.632670"
632 ( 7) 1 2.4366 ( 1.015) /_ -2.5
632 ( 8) 2 2.4715 ( 1.029) /_ -121.7
632 ( 9) 3 2.4122 ( 1.004) /_ 117.8
-----
670 ( 10) 1 2.4118 ( 1.004) /_ -3.4
670 ( 11) 2 2.4785 ( 1.032) /_ -122.0
670 ( 12) 3 2.3776 ( 0.9899) /_ 117.1
-----
ELEMENT = "Line.670671"
670 ( 10) 1 2.4118 ( 1.004) /_ -3.4
670 ( 11) 2 2.4785 ( 1.032) /_ -122.0
670 ( 12) 3 2.3776 ( 0.9899) /_ 117.1
-----
671 ( 13) 1 2.3608 ( 0.9829) /_ -5.4
671 ( 14) 2 2.4987 ( 1.04) /_ -122.4
671 ( 15) 3 2.3179 ( 0.9651) /_ 116.0
-----
ELEMENT = "Line.671680"
671 ( 13) 1 2.3608 ( 0.9829) /_ -5.4
671 ( 14) 2 2.4987 ( 1.04) /_ -122.4
671 ( 15) 3 2.3179 ( 0.9651) /_ 116.0

```



# PREPARANDO AS CARGAS PARA O TIME-SERIES



OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

General LoadShape 1 Base Frequency = 60 Hz 45

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\IEEE13BARRAS\

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 41  
Control Mode =STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

- Circuit Summary -

Clear  
//-----//  
// Files que descrevem o circuito  
Redirect substacao.dss  
Redirect linecodes.dss  
Redirect lines.dss  
Redirect loadshape.dss  
Redirect loads.dss  
Redirect capacitance.dss  
Redirect transform.dss  
Redirect regulator.dss  
Redirect switches.dss  
Redirect tensao\_t.dss  
solve

Do Selected Ctrl+D  
Save This Window  
Close Window  
Change to this Directory  
Open Selected File  
Edit Selected File  
Change Font...

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

General LoadShape 1 Base Frequency = 60 Hz

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\IEEE13BARRAS\

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 39  
Buses = 16  
Nodes = 41  
Control Mode =STATIC  
Total Iterations = 11  
Control Iterations = 3  
Max Sol Iter = 4

- Circuit Summary -

//-----//  
//Curvas de carga  
New Loadshape.1 npts=24 interval=1 mult={0.18000001 0.19000000 0.23999999 0.33000001 0.38999999 0.41000000 0.64999998 1.23000002 1.88999999 1.88999999 1.96000004 1.98000002 1.45000000}  
!mult={File=LoadShape1.csv}  
New Loadshape.2 npts=24 interval=1 mult={0.69000000 0.50999999 0.44999999 0.41999999 0.55000001 0.85000002 1.01999998 0.80000001 0.89999998 0.91000003 1.02999997 1.03999996 1.11000000}  
!mult={File=LoadShape2.csv}  
//-----//

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

General LoadShape 1 Base Frequency = 60 Hz 46

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\IEEE13BARRAS

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Snap  
 Number = 100  
 Load Mult = 1.000  
 Devices = 39  
 Buses = 16  
 Nodes = 41  
 Control Mode = Snap  
 Total Iteration = 11  
 Control Iterations = 3  
 Max Sol Iter = 4

- Circuit Summary -

Clear

//-----//  
 // Files que descrevem o circuito

Redirect substacao.dss  
 Redirect linecodes.dss  
 Redirect lines.dss  
 Redirect loadshape.dss  
 Redirect loads.dss  
 Redirect capacitors.dss  
 Redirect transformer\_sub.dss  
 Redirect transformer.dss  
 Redirect regulators.dss  
 Redirect switches.dss

Redirect tensao\_base.dss

solve

Do Selected Ctrl+D

Save This Window

Close Window

Change to this Directory

Open Selected File

Edit Selected File

Change Font...

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

General LoadShape 1 Base Frequency = 60 Hz

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\IEEE13BARRAS

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Snap  
 Number = 100  
 Load Mult = 1.000  
 Devices = 39  
 Buses = 16  
 Nodes = 41  
 Control Mode = STATIC  
 Total Iterations = 11  
 Control Iterations = 3  
 Max Sol Iter = 4

- Circuit Summary -

//-----//  
 // Dados das cargas

New Load.671 Bus1=671.1.2.3 Phases=3 Conn=Delta Model=1 daily=1 kV=4.16 kW=1155 kvar=660  
 New Load.634a Bus1=634.1 Phases=1 Conn=Wye Model=1 daily=2 kV=0.277 kW=160 kvar=110  
 New Load.634b Bus1=634.2 Phases=1 Conn=Wye Model=1 daily=2 kV=0.277 kW=120 kvar=90  
 New Load.634c Bus1=634.3 Phases=1 Conn=Wye Model=1 daily=2 kV=0.277 kW=120 kvar=90  
 New Load.645 Bus1=645.2 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=170 kvar=125  
 New Load.646 Bus1=646.2.3 Phases=1 Conn=Delta Model=2 daily=2 kV=4.16 kW=230 kvar=132  
 New Load.692 Bus1=692.3.1 Phases=1 Conn=Delta Model=5 daily=2 kV=4.16 kW=170 kvar=151  
 New Load.675a Bus1=675.1 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=485 kvar=190  
 New Load.675b Bus1=675.2 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=68 kvar=60  
 New Load.675c Bus1=675.3 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=290 kvar=212  
 New Load.611 Bus1=611.3 Phases=1 Conn=Wye Model=5 daily=2 kV=2.4 kW=170 kvar=80  
 New Load.652 Bus1=652.1 Phases=1 Conn=Wye Model=2 daily=2 kV=2.4 kW=128 kvar=86  
 New Load.670a Bus1=670.1 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=17 kvar=10  
 New Load.670b Bus1=670.2 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=66 kvar=38  
 New Load.670c Bus1=670.3 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=117 kvar=68

# RESULTADOS DO TIME-SERIES

The screenshot displays the OpenDSS Data Directory application window. The title bar indicates the path: `C:\Users\HP\Desktop\openDSS\Paulo_Example\DSSFiles\`. The interface includes a menu bar (File, Edit, Do, Set, Make, Export, Show, Visualize, Plot, Reset, Help) and a toolbar with icons for file operations and simulation control. A status bar at the top right shows `Base Frequency = 60 Hz`.

The main window is divided into several sections:

- Left Panel (Results for Actor ID # 1):** Displays simulation parameters and status:
  - CPU selected : 0
  - Status = SOLVED
  - Solution Mode = Daily
  - Number = 24
  - Load Mult = 1.000
  - Devices = 40
  - Buses = 16
  - Nodes = 41
  - Control Mode = STATIC
  - Total Iterations = 0
  - Control Iterations = 0
  - Max Sol Iter = 0
- Command Window (Center):** Contains the following text:
 

```

Clear
//-----//
// Files que descrevem o circuito
Redirect subestacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitors.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss
Redirect tensao_base.dss
New monitor.demanda element=line.650632 terminal=1 mode=1 ppolar=no
set mode=daily
set number=24
set steosize=1h
solve
      
```

 A blue arrow points to the `New monitor.demanda` command.
- Bottom Panel (Messages):** Shows the current file being edited: `MASTER_RedeTeste13Barras.dss`. Other files listed include `lines.dss`, `loadshape.dss`, and `loads.dss`.

The status bar at the bottom of the window shows: `Memory: 34956K | Circuit Status: SOLVED | Total Iterations = 0 | Control Iterations = 0 | Max Solution Iterations = 0`.

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Plot Reset Help

PElements Load Base Frequency = 60 Hz 48

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\IEEE13BARRAS

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 24  
 Load Mult = 1.000  
 Devices = 40  
 Buses = 16  
 Nodes = 41  
 Control Mode = STATIC  
 Total Iterations = 13  
 Control Iterations = 3  
 Max Sol Iter = 5

- Circuit Summary -

Year = 0  
 Hour = 24  
 Max pu. voltage = 1.0588  
 Min pu. voltage = 0.99057  
 Total Active Power: 2.40879 MW  
 Total Reactive Power: 0.881567 Mvar  
 Total Active Losses: 0.0530838 MW, (2.204 %)  
 Total Reactive Losses: 0.145278 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

Clear

```
//-----//
// Files que descrevem o circuito
Redirect subestacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitors.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss

Redirect tensao_base.dss

New monitor.demanda element=line.650632 terminal=1 mode=1 ppol

set mode=daily
set number=24
set stepsize=1h

solve
```

Select Channel(s)

Select One or More Columns  
From CSV File

- 1. P1 (kW)
- 2. Q1 (kvar)
- 3. P2 (kW)
- 4. Q2 (kvar)
- 5. P3 (kW)
- 6. Q3 (kvar)

OK Cancel

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss

Messages Main

Summary Results

Memory: 35408K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max


IEEE13BARRAS\_MONITOR-DEMANDA-ch1-ch3-ch5.DSV

File Edit View About

Mag demanda: P1 (kW), P2 (kW), P3 (kW)

Time, H

# RESULTADOS DE UMA HORA DO DIA



Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 24  
 Load Mult = 1.000  
 Devices = 40  
 Buses = 16  
 Nodes = 41  
 Control Mode =STATIC  
 Total Iterations = 13  
 Control Iterations = 3  
 Max Sol Iter = 5

- Circuit Summary -

Year = 0  
 Hour = 24  
 Max pu. voltage = 1.0588  
 Min pu. voltage = 0.99057  
 Total Active Power: 2.40879 MW  
 Total Reactive Power: 0.881567 Mvar  
 Total Active Losses: 0.0530838 MW, (2.204 %)  
 Total Reactive Losses: 0.145278 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

```

Clear
//-----//
// Files que descrevem o circuito
Redirect substacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitors.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss

Redirect tensao_base.dss

New monitor.demanda element=line.650632 terminal=1 mode=1 ppolar=no

set mode=daily
set number=1
set stepsize=1h
set hour=12
    
```

solve

Main MASTER\_RedeTeste

Messages Main

Summary Results

IEEE13BARRAS\_EventLog - Notepad

```

File Edit Format View Help

Hour=13, Sec=0, ControlIter=1, Element=Regulator.regfasec, Action= CHANGED 8 TAPS TO 1.05.
Hour=13, Sec=0, ControlIter=1, Element=Regulator.regfaseb, Action= CHANGED 6 TAPS TO 1.0375.
Hour=13, Sec=0, ControlIter=1, Element=Regulator.regfasea, Action= CHANGED 8 TAPS TO 1.05.
Hour=13, Sec=0, ControlIter=2, Element=Regulator.regfasec, Action= CHANGED 2 TAPS TO 1.0625.
Hour=13, Sec=0, ControlIter=2, Element=Regulator.regfaseb, Action= CHANGED 2 TAPS TO 1.05.
Hour=13, Sec=0, ControlIter=2, Element=Regulator.regfasea, Action= CHANGED 2 TAPS TO 1.0625.
Hour=13, Sec=0, ControlIter=3, Element=Regulator.regfasec, Action= CHANGED 1 TAPS TO 1.06875.
Hour=13, Sec=0, ControlIter=3, Element=Regulator.regfasea, Action= CHANGED 1 TAPS TO 1.06875.
    
```

# PV SYSTEM

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\

File Edit Do Set Make Export Show Visualize Plot Reset Help

PCelements Load

C V

C V P

Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\IEEE13BARRAS

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 1  
 Load Mult = 1.000  
 Devices = 40  
 Buses = 16  
 Nodes = 41  
 Control Mode =STATIC  
 Total Iterations = 15  
 Control Iterations = 4  
 Max Sol Iter = 4

- Circuit Summary -

Year = 0  
 Hour = 13  
 Max pu. voltage = 1.0687  
 Min pu. voltage = 0.94734  
 Total Active Power: 4.3911 MW  
 Total Reactive Power: 2.37457  
 Mvar  
 Total Active Losses: 0.169998  
 MW, (3.871 %)  
 Total Reactive Losses: 0.505602  
 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

Clear

//-----//  
 // Files que descrevem o circuito

Redirect substacao.dss  
 Redirect linecodes.dss  
 Redirect lines.dss  
 Redirect loadshape.dss  
 Redirect loads.dss  
 Redirect capacitors.dss  
 Redirect transformer\_sub.dss  
 Redirect transformer.dss  
 Redirect regulators.dss  
 Redirect switches.dss

Redirect pvsystemexample.dss

Redirect tensao\_base.dss

New monitor.demanda element=line.650632 terminal=1 mode=1 ppolar=no

set mode=daily  
 set number=1  
 set stepsize=1h  
 set hour=12

solve

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexamp

Messages Main

Summary Results

Memory: 32784K Circuit Status: SOLVED Total Iterations = 15. Control Iterations

Results

Summary Results

Results

Memory: 32784K Circuit Status: SOLVED Total Iterations = 15. Control Iterations = 4. Max Solution Iterations = 4

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 1  
 Load Mult = 1.000  
 Devices = 40  
 Buses = 16  
 Nodes = 41  
 Control Mode =STATIC  
 Total Iterations = 15  
 Control Iterations = 4  
 Max Sol Iter = 4

- Circuit Summary -

Year = 0  
 Hour = 13  
 Max pu. voltage = 1.0687  
 Min pu. voltage = 0.94734  
 Total Active Power: 4.3911 MW  
 Total Reactive Power: 2.37457  
 Mvar  
 Total Active Losses: 0.169998  
 MW, (3.871 %)  
 Total Reactive Losses: 0.505602  
 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

// P-T curve is per unit of rated Pmpp vs temperature  
 // This one is for a Pmpp stated at 25 deg  
 New XYCurve.MyPvsT npts=4 xarray=[0 25 75 100] yarray=[1.2 1.0 0.8 0.6]

// efficiency curve is per unit eff. vs per unit power  
 New XYCurve.MyEff npts=4 xarray=[.1 .2 .4 1.0] yarray=[.86 .9 .93 .97]

// per unit irradiance curve (per unit if "irradiance" property)  
 New Loadshape.MyIrrad npts=24 interval=1 mult=[0 0 0 0 0 1.2 3 .5 .8 .9 1.0 1.0 .99 .9 .7 .4 .1 0 0 0 0]

// 24-hr temp shape curve  
 New Tshape.MyTemp npts=24 interval=1 temp=[25, 25, 25, 25, 25, 25, 25, 35, 40, 45, 50 60 60 55 40 35 30 25 25 25 25 25]

// pv definition

New PVSystem.PV phases=3 bus1=trafo\_pv kV=0.48 kVA=2000 irrad=98 Pmpp=1800 temperature=25 PF=1 %cutin=0.1 %cutout=0.1 effcurve=Myeff P-TCurve=MyPvsT Daily=MyIrrad TDaily=MyTemp

New PVSystem.PV phases=3 bus1=trafo\_pv kV=0.48 kVA=600 irrad=98 Pmpp=500 temperature=25 PF=1 %cutin=0.1 %cutout=0.1 effcurve=Myeff P-TCurve=MyPvsT Daily=MyIrrad TDaily=MyTemp Idef

New Transformer.pv\_up phases=3 xhl=5.750000  
 ~ wdg=1 bus=trafo\_pv kV=0.48 kVA=750.000000 conn=wye  
 ~ wdg=2 bus=680 kV=4.16 kVA=750.000000 conn=wye

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\pvsystemexample.dss

Summary Results


Summary Results

Summary Results

Memory: 32784K Circuit Status: SOLVED Total Iterations = 15. Control Iterations = 4. Max Solution Iterations = 4


Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 41  
Buses = 17  
Nodes = 44  
Control Mode =STATIC  
Total Iterations = 0  
Control Iterations = 0  
Max Sol Iter = 0  
- Circuit Summary -

**Clear**  
//-----  
// Files que descrevem o circuito  
  
Redirect substacao.dss  
Redirect linecodes.dss  
Redirect lines.dss  
Redirect loadshape.dss  
Redirect loads.dss  
Redirect capacitors.dss  
Redirect transformer\_sub.dss  
Redirect transformer.dss  
Redirect regulators.dss  
Redirect switches.dss  
  
Redirect pssystemexample.dss  
  
Redirect tensao\_base.dss  
  
New monitor.demanda element=line.6  
  
set mode=daily  
set number=1  
set stepsize=1h  
set hour=12  
  
solve



# PV SYSTEM RESULTADOS

Fig: Diagrama unifilar da rede teste IEEE 13 barras com a presença do sistema fotovoltaico



Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Snap  
Number = 100  
Load Mult = 1.000  
Devices = 41  
Buses = 17  
Nodes = 44  
Control Mode =STATIC  
Total Iterations = 0  
Control Iterations = 0  
Max Sol Iter = 0

- Circuit Summary -

```
Clear
//-----//
// Files que descrevem o circuito
Redirect subestacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitors.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss
Redirect pvsystemexample.dss
Redirect tensao_base.dss
New monitor.PV_powers element=PVSystem.PV terminal=1 mode=1 ppolar=no
set mode=daily
set number=24
set stepsize=1h
solve
```

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss

Messages Main


Summary Results

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Daily  
Number = 24  
Load Mult = 1.000  
Devices = 42  
Buses = 17  
Nodes = 44  
Control Mode =STATIC  
Total Iterations = 13  
Control Iterations = 3  
Max Sol Iter = 5

- Circuit Summary -

Year = 0  
Hour = 24  
Max pu. voltage = 1.0588  
Min pu. voltage = 0.99057  
Total Active Power: 2.40879 MW  
Total Reactive Power: 0.881568  
Mvar  
Total Active Losses: 0.0530838  
MW, (2.204 %)  
Total Reactive Losses: 0.145279  
Mvar  
Frequency = 60 Hz  
Mode = Daily  
Control Mode = STATIC  
Load Model = PowerFlow

```
Clear  
//-----  
// Files que descrevem o circuito  
  
Redirect subestacao.dss  
Redirect linecodes.dss  
Redirect lines.dss  
Redirect loadshape.dss  
Redirect loads.dss  
Redirect capacitors.dss  
Redirect transformer_sub.dss  
Redirect transformer.dss  
Redirect regulators.dss  
Redirect switches.dss  
  
Redirect pvsystemexample.dss  
  
Redirect tensao_base.dss  
  
New monitor.PV_powers element  
  
set mode=daily  
set number=24  
set stepsize=1h  
  
solve
```



OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

General LoadShape

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss C:\Users\HP\

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 24  
 Load Mult = 1,000  
 Devices = 42  
 Buses = 17  
 Nodes = 44  
 Control Mode =STATIC  
 Total Iterations = 13  
 Control Iterations = 3  
 Max Sol Iter = 5

- Circuit Summary -

Year = 0  
 Hour = 24  
 Max pu. voltage = 1.0588  
 Min pu. voltage = 0.99057  
 Total Active Power: 2.40879 MW  
 Total Reactive Power: 0.881568  
 Mvar  
 Total Active Losses: 0.0530838 MW, (2.204 %)  
 Total Reactive Losses: 0.145279 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

---

Clear

//-----  
 // Files que descrevem o circuito

**Redirect subestacao.dss**  
**Redirect linecodes.dss**  
**Redirect lines.dss**  
**Redirect loadshape.dss**  
**Redirect loads.dss**  
**Redirect capacitors.dss**  
**Redirect transformer\_sub.dss**  
**Redirect transformer.dss**  
**Redirect regulators.dss**  
**Redirect switches.dss**

**Redirect pvsystemexample.dss**

**Redirect tensao\_base.dss**

**New monitor.PV\_powers element=Transformer.pv\_up terminal=1 mode=1 ppolar=no**

**set mode=daily**  
**set number=24**  
**set stepsize=1h**

**solve**

IEEE13BARRAS\_MONITOR-PV\_POWERS-ch1-ch3-ch5.DSV

File Edit View About

Mag pv\_powers: P1 (kW), P2 (kW), P3 (kW)

Time, H

Time (H)	Mag (kW)
0.0	0
5.0	0
6.0	0
7.0	10
8.0	25
9.0	45
10.0	75
11.0	110
12.0	125
13.0	130
14.0	130
15.0	130
16.0	125
17.0	100
18.0	60
19.0	15
20.0	0
24.0	0

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss

Messages Main

Summary Results

Memory: 16000K

Circuit Status: SOLVED

Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Daily  
Number = 24  
Load Mult = 1.000  
Devices = 43  
Buses = 17  
Nodes = 44  
Control Mode =STATIC  
Total Iterations = 13  
Control Iterations = 3  
Max Sol Iter = 5

- Circuit Summary -

Year = 0  
Hour = 24  
Max pu. voltage = 1.0588  
Min pu. voltage = 0.99057  
Total Active Power: 2.40879 MW  
Total Reactive Power: 0.881568 Mvar  
Total Active Losses: 0.0530838 MW, (2.204 %)  
Total Reactive Losses: 0.145279 Mvar  
Frequency = 60 Hz  
Mode = Daily  
Control Mode = STATIC  
Load Model = PowerFlow

```
Clear
//-----//
// Files que descrevem o circuito

Redirect subestacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitors.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss

Redirect pvsystemexample.dss

Redirect tensao_base.dss






New monitor.PV_powers element=Transformer.pv_up terminal=1 mode=1 ppolar=no
New monitor.PV_variables element=PVSystem.PV terminal=1 mode=3

set mode=daily
set number=24
set stepsize=1h

solve
```

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss

Messages Main



OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault Vsource

Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 24  
 Load Mult = 1.000  
 Devices = 44  
 Buses = 17  
 Nodes = 44  
 Control Mode =STATIC  
 Total Iterations = 13  
 Control Iterations = 3  
 Max Sol Iter = 5

- Circuit Summary -

Year = 0  
 Hour = 24  
 Max pu. voltage = 1.0588  
 Min pu. voltage = 0.99057  
 Total Active Power: 2.40879 MW  
 Total Reactive Power: 0.881568 Mvar  
 Total Active Losses: 0.0530838 MW, (2.204 %)  
 Total Reactive Losses: 0.145279 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

```

Clear
//-----
// Files que descrevem o circuito
Redirect substacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitors.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss


Redirect pvsystemexample.dss

Redirect tensao_base.dss


New monitor.PV_powers element=Transformer.pv_up terminal=1 mode=1 ppolar=no
New monitor.PV_variables element=PVSystem.PV terminal=1 mode=3
New monitor.PV_voltage element=PVSystem.PV terminal=1 mode=0

set mode=daily
set number=24
set stepsize=1h

solve
  
```



# PV SYSTEM COMPARANDO A DEMANDA



OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault Vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 24  
 Load Mult = 1.000  
 Devices = 45  
 Buses = 17  
 Nodes = 44  
 Control Mode = STATIC  
 Total Iterations = 13  
 Control Iterations = 3  
 Max Sol Iter = 5

- Circuit Summary -

Year = 0  
 Hour = 24  
 Max pu. voltage = 1.0588  
 Min pu. voltage = 0.99057  
 Total Active Power: 2.40879 MW  
 Total Reactive Power: 0.881568 Mvar  
 Total Active Losses: 0.0530838 MW, (2.204 %)  
 Total Reactive Losses: 0.145279 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

```

Clear
//-----//
// Files que descrevem o circuito
Redirect substacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitors.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss

Redirect pvssystemexample.dss
PVSystem.PV.enable=yes


Redirect tensao_base.dss

New monitor.PV_powers element=Transformer.pv_up terminal=1 mode=1 ppolar=no
New monitor.PV_variables element=PVSystem.PV terminal=1 mode=3
New monitor.PV_voltage element=PVSystem.PV terminal=1 mode=0

New monitor.demanda element=line.650632 terminal=1 mode=1 ppolar=no

set mode=daily
set number=24
set stepsize=1h

solve
  
```



OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault Vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 24  
 Load Mult = 1.000  
 Devices = 45  
 Buses = 17  
 Nodes = 44  
 Control Mode = STATIC  
 Total Iterations = 13  
 Control Iterations = 3  
 Max Sol Iter = 5

- Circuit Summary -

Year = 0  
 Hour = 24  
 Max pu. voltage = 1.0588  
 Min pu. voltage = 0.99057  
 Total Active Power: 2.40879 MW  
 Total Reactive Power: 0.881568 Mvar  
 Total Active Losses: 0.0530838 MW, (2.204 %)  
 Total Reactive Losses: 0.145279 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

```

// P-T curve is per unit of rated Pmpp vs temperature
// This one is for a Pmpp stated at 25 deg
New XYCurve.MyPvsT npts=4 xarray=[0 25 75 100] yarray=[1.2 1.0 0.0 0.6]

// efficiency curve is per unit eff vs per unit power
New XYCurve.MyEff npts=4 xarray=[.1 .2 .4 1.0] yarray=[.86 .9 .93 .97]

// per unit irradiance curve [per unit if "irradiance" property]
New Loadshape.MyIrrad npts=24 interval=1 mult=[0 0 0 0 0 1.2 3 .5 .8 .9 1.0 1.0 .99 .9 7 .4 .10 0 0 0 0]

// 24-hr temp shape curve
New Tshape.MyTemp npts=24 interval=1 temp=[25, 25, 25, 25, 25, 25, 25, 35, 40, 45, 50 60 60 55 40 35 30 25 25 25 25 25]

// pv definition
INew PVSystem.PV_phases=3 bus1=trafo_pV kV=0.48 kVA=2000 irrad=.98 Pmpp=1800 temperature=25 PF=1 %cutin=0.1 %cutout=0.1 effcurve=Myeff P-TCurve=MyPvsT Daily=MyIrrad TDaily=MyTemp I
New PVSystem.PV_phases=3 bus1=trafo_pV kV=0.48 kVA=3000 irrad=.98 Pmpp=3000 temperature=25 PF=1 %cutin=0.1 %cutout=0.1 effcurve=Myeff P-TCurve=MyPvsT Daily=MyIrrad TDaily=MyTemp I

New Transformer.pv_up_phases=3 xhl=5.750000
~ wdg=1 bus=trafo_pV kV=0.48 kVA=750.000000 conn=weye
~ wdg=2 bus=680 kV=4.16 kVA=750.000000 conn=weye
  
```

# photovoltaic system (Exemplo para a aula)



Carlos Frederico Meschini Almeida

[cfmalmeida@usp.br](mailto:cfmalmeida@usp.br)

11 987822361

# ASSESSING THE .DSS FILES OF THESES

- Open the following file from Paulo\_Example: MASTER\_RedeTeste13Barras.dss



# SUBSTATIONS

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.v

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Daily  
Number = 24  
Load Mult = 1.000  
Devices = 45  
Buses = 17  
Nodes = 44  
Control Mode = STATIC  
Total Iterations = 13  
Control Iterations = 3  
Max Sol Iter = 5

- Circuit Summary -  
Year = 0  
Hour = 24  
Max pu. voltage = 1.0588  
Min pu. voltage = 0.99057  
Total Active Power: 2.4087 MW  
Total Reactive Power: 0.801568 Mvar  
Total Active Losses: 0.0530838 MW, (2.204 %)  
Total Reactive Losses: 0.145279 Mvar  
Frequency = 60 Hz  
Mode = Daily  
Control Mode = STATIC  
Load Model = PowerFlow

//-----//  
// Escola Politécnica da USP  
// PEA  
// Autor  
// Nome: Paulo Radatz  
// NUSP: 6905680  
//-----//  
// Modelagem da rede teste IEEE 13 barras  
//-----//  
// No Apêndice A do meu TCC se encontra toda a explicação para rodar os diferentes cenários.  
//-----//  
// Reinicia o programa  
Clear  
//-----//  
// Files que descrevem o circuito  
Redirect subestacao.dss  
Redirect linecodes.dss  
Redirect lines.dss  
Redirect loadshape.dss  
Redirect loads.dss  
Redirect capacitores.dss  
Redirect transformer\_sub.dss  
Redirect transformer.dss  
Redirect regulators.dss  
Redirect switches.dss  
!Redirect wind\_power.dss  
!Redirect wind\_control.dss  
!Redirect pvsystemexample.dss  
!Redirect volt\_var\_pv.dss  
!Redirect storage\_power.dss

Right-click

- Do Selected Ctrl-D
- Save This Window
- Close Window
- Change to this Directory
- Open Selected File
- Edit Selected File
- Change Font...

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss subestacao.dss subestacao.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.dss

Summary Results

Memory: 20712K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

OpenDSS Data Directory: C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.v

Results for Actor ID # 1  
CPU selected : 0  
Status = SOLVED  
Solution Mode = Daily  
Number = 24  
Load Mult = 1.000  
Devices = 45  
Buses = 17  
Nodes = 44  
Control Mode = STATIC  
Total Iterations = 13  
Control Iterations = 3  
Max Sol Iter = 5

- Circuit Summary -  
Year = 0  
Hour = 24  
Max pu. voltage = 1.0588  
Min pu. voltage = 0.99057  
Total Active Power: 2.40879 MW  
Total Reactive Power: 0.801568 Mvar  
Total Active Losses: 0.0530838 MW, (2.204 %)  
Total Reactive Losses: 0.145279 Mvar  
Frequency = 60 Hz  
Mode = Daily  
Control Mode = STATIC  
Load Model = PowerFlow

//-----//  
// Dados do equivalente  
New Circuit IEEE13BARRAS  
~ basekv=115 pu=1.0 phases=3 bus1=SourceBus  
~ Angle=30  
~ MVAsc3=1000000000 MVAsc1=1000000000  
AddBusMarker Bus=SourceBus Code=36 color=Red size=2  
//-----//

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss subestacao.dss subestacao.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\subestacao.dss

Summary Results

Memory: 20712K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

5:45 PM 11/26/2020

# LINE CODES

The image shows two instances of the OpenDSS software interface. The left window displays a script for a test network, and the right window displays a list of line codes. A context menu is overlaid on the left window, showing options for file operations.

**Left Window Script:**

```
//-----//
// Escola Politécnica da USP
// PEA
// Autor
// Nome: Paulo Radatz
// NUSP: 6905560
//-----//
// Modelagem da rede teste IEEE 13 barras
//-----//
// No Apêndice A do meu TCC se encontra toda a explicação para rodar os diferentes cenários.
//-----//
//Reinicia o programa
Clear
//-----//
// Files que descrevem o circuito
Redirect subestacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitores.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss
!Redirect wind_power.dss
!Redirect wind_control.dss
!Redirect pvsystemexample.dss
!Redirect volt_var_pv.dss
!Redirect storage_power.dss
Main MASTER_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss subestacao.dss subestacao.dss linecodes
```

**Right Window Line Codes:**

```
//-----//
// Dados dos arranjos.
// 601
New linecode.601 nphases=3 BaseFreq=60
~ rmatrix = (0.2153 | 0.0969 0.2097 | 0.0982 0.0954 0.2121)
~ xmatrix = (0.6325 | 0.3117 0.6511 | 0.2632 0.2392 0.6430)
~ cmatrix = (10.3833 | -3.2894 9.8228 | -2.0759 -1.2225 9.2936)
~ units=km
// 602
New linecode.602 nphases=3 BaseFreq=60
~ rmatrix = (0.4676 | 0.0982 0.4645 | 0.0969 0.0954 0.4621)
~ xmatrix = (0.7341 | 0.2632 0.7446 | 0.3117 0.2392 0.7526)
~ cmatrix = (9.3931 | -1.7828 8.5369 | -2.7862 -1.0859 8.9508)
~ units=km
// 603
New linecode.603 nphases=2 BaseFreq=60
~ rmatrix = (0.8261 | 0.1204 0.8226)
~ xmatrix = (0.8370 | 0.2953 0.8431)
~ cmatrix = (7.7626 | -1.4833 7.6902)
~ units=km
// 604
New linecode.604 nphases=2 BaseFreq=60
~ rmatrix = (0.8226 | 0.1204 0.8261)
~ xmatrix = (0.8431 | 0.2953 0.8370)
~ cmatrix = (7.6902 | -1.4833 7.7626)
~ units=km
// 605
New linecode.605 nphases=1 BaseFreq=60
~ rmatrix = (0.8259)
~ xmatrix = (0.8373)
```

**Context Menu:**

- Do Selected (Ctrl-D)
- Save This Window
- Close Window
- Change to this Directory
- Open Selected File
- Edit Selected File
- Change Font...

**Bottom Status Bar:**

Memory: 20712K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

# LINES

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.v

```

Results for Actor ID # 1
CPU selected : 0
Status = SOLVED
Solution Mode = Daily
Number = 24
Load Mult = 1.000
Devices = 45
Buses = 17
Nodes = 44
Control Mode =STATIC
Total Iterations = 13
Control Iterations = 3
Max Sol Iter = 5

- Circuit Summary -
Year = 0
Hour = 24
Max pu. voltage = 1.0588
Min pu. voltage = 0.99057
Total Active Power: 2.40879 MW
Total Reactive Power: 0.881568 Mvar
Total Active Losses: 0.0530838 MW, (2.204 %)
Total Reactive Losses: 0.145279 Mvar
Frequency = 60 Hz
Mode = Daily
Control Mode = STATIC
Load Model = PowerFlow

//-----//
// Escola Politécnica da USP
// PEA
// Autor
// Nome: Paulo Radatz
// NUSP: 6905560
//-----//
// Modelagem da rede teste IEEE 13 barras
//-----//
// No Apêndice A do meu TCC se encontra toda a explicação para rodar os diferentes cenários.
//-----//
//Reinicia o programa
Clear
//-----//
// Files que descrevem o circuito
Redirect substacao.dss
Redirect linecodes.dss
Redirect lines.dss
Redirect loadshape.dss
Redirect loads.dss
Redirect capacitores.dss
Redirect transformer_sub.dss
Redirect transformer.dss
Redirect regulators.dss
Redirect switches.dss
IRedirect wind_power.dss
IRedirect wind_control.dss
IRedirect pvsystemexample.dss
IRedirect volt_var_pv.dss
IRedirect storage_power.dss
Main MASTER_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss lines.dss
Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo_Example\DSSFiles\MASTER_RedeTeste13Barras.dss
Summary Results
Memory: 20712K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

```

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras.v

```

Results for Actor ID # 1
CPU selected : 0
Status = SOLVED
Solution Mode = Daily
Number = 24
Load Mult = 1.000
Devices = 45
Buses = 17
Nodes = 44
Control Mode =STATIC
Total Iterations = 13
Control Iterations = 3
Max Sol Iter = 5

- Circuit Summary -
Year = 0
Hour = 24
Max pu. voltage = 1.0588
Min pu. voltage = 0.99057
Total Active Power: 2.40879 MW
Total Reactive Power: 0.881568 Mvar
Total Active Losses: 0.0530838 MW, (2.204 %)
Total Reactive Losses: 0.145279 Mvar
Frequency = 60 Hz
Mode = Daily
Control Mode = STATIC
Load Model = PowerFlow

//-----//
//Dados das linhas.
//Observação: Na barra 670 A@ colocado o equivalente da carga distribuída.
New Line.650632 Phases=3 Bus1=Reg.1.2.3 Bus2=632.1.2.3 LineCode=601 Length=2000 units=ft
New Line.632670 Phases=3 Bus1=632.1.2.3 Bus2=670.1.2.3 LineCode=601 Length=667 units=ft
New Line.670671 Phases=3 Bus1=670.1.2.3 Bus2=671.1.2.3 LineCode=601 Length=1333 units=ft
New Line.671680 Phases=3 Bus1=671.1.2.3 Bus2=680.1.2.3 LineCode=601 Length=1000 units=ft
New Line.632633 Phases=3 Bus1=632.1.2.3 Bus2=633.1.2.3 LineCode=602 Length=500 units=ft
New Line.632645 Phases=2 Bus1=632.3.2 Bus2=645.3.2 LineCode=603 Length=500 units=ft
New Line.645646 Phases=2 Bus1=645.3.2 Bus2=646.3.2 LineCode=603 Length=300 units=ft
New Line.692675 Phases=3 Bus1=692.1.2.3 Bus2=675.1.2.3 LineCode=606 Length=500 units=ft
New Line.671684 Phases=2 Bus1=671.1.3 Bus2=684.1.3 LineCode=604 Length=300 units=ft
New Line.684611 Phases=1 Bus1=684.3 Bus2=611.3 LineCode=605 Length=300 units=ft
New Line.684652 Phases=1 Bus1=684.1 Bus2=652.1 LineCode=607 Length=800 units=ft

Main MASTER_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss lines.dss
Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo_Example\DSSFiles\lines.dss
Summary Results
Memory: 20712K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

```

Do Selected Ctrl+D

- Save This Window
- Close Window
- Change to this Directory
- Open Selected File
- Edit Selected File
- Change Font...



- Perform the same action to see the following codes:
- Load shapes
- Loads
- Capacitors
- Transformer
- Regulators
- switches

# LOAD SHAPES

The screenshot displays the OpenDSS software interface. The top menu bar includes File, Edit, Do, Set, Make, Export, Show, Visualize, Plot, Reset, and Help. The toolbar contains icons for file operations and simulation controls, with a status indicator for 'Base Frequency = 60 Hz'. The main window title is 'C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras...'. A warning message states: 'Warning: Duplicate new element definition: "Transformer.Subestacao"E'.

The left sidebar shows the following results for Actor ID # 1:

- CPU selected : 0
- Status = SOLVED
- Solution Mode = Daily
- Number = 24
- Load Mult = 1.000
- Devices = 45
- Buses = 17
- Nodes = 44
- Control Mode = STATIC
- Total Iterations = 13
- Control Iterations = 3
- Max Sol Iter = 5

A circuit summary is provided below:

- Year = 0
- Hour = 24
- Max pu. voltage = 1.0588
- Min pu. voltage = 0.99057
- Total Active Power: 2.40879 MW
- Total Reactive Power: 0.881568 Mvar
- Total Active Losses: 0.0530838 MW, (2.204 %)
- Total Reactive Losses: 0.145279 Mvar
- Frequency = 60 Hz
- Mode = Daily
- Control Mode = STATIC
- Load Model = PowerFlow

The main window displays the following configuration text:

```
//-----//  
//Curvas de carga  
New Loadshape.1 npts=24 interval=1 mult=(0.18000001 0.19000000 0.23999999 0.33000001 0.38999999 0.41000000 0.64999998 1.23000002 1.88999999 1.88999999 1.96000004 1.98000002 1.45000001  
!mult={File=LoadShape1.csv}  
New Loadshape.2 npts=24 interval=1 mult=(0.69000000 0.50999999 0.44999999 0.41999999 0.55000001 0.85000002 1.01999998 0.80000001 0.89999998 0.91000003 1.02999997 1.03999996 1.11000001  
!mult={File=LoadShape2.csv}  
//-----//
```

The bottom status bar shows: Memory: 25416K, Circuit Status: SOLVED, Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5.

# LOADS

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault Vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras. Warning: Duplicate new element definition: "Transformer.Subestacao"E

Results for Actor ID # 1

CPU selected : 0

Status = SOLVED

Solution Mode = Daily

Number = 24

Load Mult = 1.000

Devices = 45

Buses = 17

Nodes = 44

Control Mode =STATIC

Total Iterations = 13

Control Iterations = 3

Max Sol Iter = 5

- Circuit Summary -

Year = 0

Hour = 24

Max pu. voltage = 1.0588

Min pu. voltage = 0.99057

Total Active Power: 2.40879 MW

Total Reactive Power: 0.881568 Mvar

Total Active Losses: 0.0530838 MW, (2.204 %)

Total Reactive Losses: 0.145279 Mvar

Frequency = 60 Hz

Mode = Daily

Control Mode = STATIC

Load Model = PowerFlow

```
//-----//
// Dados das cargas
New Load.671 Bus1=671.1.2.3 Phases=3 Conn=Delta Model=1 daily=1 kV=4.16 kW=1155 kvar=660
New Load.634a Bus1=634.1 Phases=1 Conn=Wye Model=1 daily=2 kV=0.277 kW=160 kvar=110
New Load.634b Bus1=634.2 Phases=1 Conn=Wye Model=1 daily=2 kV=0.277 kW=120 kvar=90
New Load.634c Bus1=634.3 Phases=1 Conn=Wye Model=1 daily=2 kV=0.277 kW=120 kvar=90
New Load.645 Bus1=645.2 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=170 kvar=125
New Load.646 Bus1=646.2.3 Phases=1 Conn=Delta Model=2 daily=2 kV=4.16 kW=230 kvar=132
New Load.692 Bus1=692.3.1 Phases=1 Conn=Delta Model=5 daily=2 kV=4.16 kW=170 kvar=151
New Load.675a Bus1=675.1 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=485 kvar=190
New Load.675b Bus1=675.2 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=68 kvar=60
New Load.675c Bus1=675.3 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=290 kvar=212
New Load.611 Bus1=611.3 Phases=1 Conn=Wye Model=5 daily=2 kV=2.4 kW=170 kvar=80
New Load.652 Bus1=652.1 Phases=1 Conn=Wye Model=2 daily=2 kV=2.4 kW=128 kvar=86
New Load.670a Bus1=670.1 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=17 kvar=10
New Load.670b Bus1=670.2 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=66 kvar=38
New Load.670c Bus1=670.3 Phases=1 Conn=Wye Model=1 daily=2 kV=2.4 kW=117 kvar=68
//-----//
```

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss lines.dss loadshape.dss loads.dss capacitors.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\loads.dss

Summary Results

Memory: 25416K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

# CAPACITORS

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault Vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras. Warning: Duplicate new element definition: "Transformer.Substacao"E

```

Results for Actor ID # 1
CPU selected : 0
Status = SOLVED
Solution Mode = Daily
Number = 24
Load Mult = 1.000
Devices = 45
Buses = 17
Nodes = 44
Control Mode =STATIC
Total Iterations = 13
Control Iterations = 3
Max Sol Iter = 5

- Circuit Summary -

Year = 0
Hour = 24
Max pu. voltage = 1.0588
Min pu. voltage = 0.99057
Total Active Power: 2.40879 MW
Total Reactive Power: 0.881568 Mvar
Total Active Losses: 0.0530838 MW, (2.204 %)
Total Reactive Losses: 0.145279 Mvar
Frequency = 60 Hz
Mode = Daily
Control Mode = STATIC
Load Model = PowerFlow
-----

//-----//
// Dados dos capacitores.
New Capacitor.Cap1 Bus1=675 phases=3 kvar=600 kV=4.16
New Capacitor.Cap2 Bus1=611.3 phases=1 kvar=100 kV=2.4
//-----//

```

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss lines.dss loadshape.dss loads.dss capacitors.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\capacitors.dss

Summary Results

Memory: 25416K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

# TRANSFORMER

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras. Warning: Duplicate new element definition: "Transformer.Subestacao"E

```

Results for Actor ID # 1
CPU selected : 0
Status = SOLVED
Solution Mode = Daily
Number = 24
Load Mult = 1.000
Devices = 45
Buses = 17
Nodes = 44
Control Mode =STATIC
Total Iterations = 13
Control Iterations = 3
Max Sol Iter = 5

- Circuit Summary -

Year = 0
Hour = 24
Max pu. voltage = 1.0588
Min pu. voltage = 0.99057
Total Active Power: 2.40879 MW
Total Reactive Power: 0.881568 Mvar
Total Active Losses: 0.0530838 MW, (2.204 %)
Total Reactive Losses: 0.145279 Mvar
Frequency = 60 Hz
Mode = Daily
Control Mode = STATIC
Load Model = PowerFlow

```

```

//-----//
// Dados do transformador.
//-----//
New Transformer.XFM1 phases=3 windings=2 xhl=2
~ wdg=1 bus=633 conn=wye kV=4.16 kva=500 %r=.55
~ wdg=2 bus=634 conn=wye kV=0.480 kva=500 %r=.55
//-----//

```

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss transformer.dss regulators.dss switches.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\transformer.dss

Summary Results

Memory: 25416K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

# REGULATORS

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault vsource Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras. Warning: Duplicate new element definition: "Transformer.Subestacao"E

Results for Actor ID # 1  
 CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 24  
 Load Mult = 1.000  
 Devices = 45  
 Buses = 17  
 Nodes = 44  
 Control Mode =STATIC  
 Total Iterations = 13  
 Control Iterations = 3  
 Max Sol Iter = 5

- Circuit Summary -

Year = 0  
 Hour = 24  
 Max pu. voltage = 1.0588  
 Min pu. voltage = 0.99057  
 Total Active Power: 2.40879 MW  
 Total Reactive Power: 0.881568 Mvar  
 Total Active Losses: 0.0530838 MW, (2.204 %)  
 Total Reactive Losses: 0.145279 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

```
//-----//
// Dados dos reguladores.
//Fase A
New Transformer.RegFaseA phases=1 xhl=0.01 %LoadLoss=0.001
~ wdg=1 bus=650.1 kV=2.4 kva=1666.7
~ wdg=2 bus=Reg.1 kV=2.4 kva=1666.7
New regcontrol.RegFaseA transformer=RegFaseA
~ winding=2 vreg=122 band=2 ptratio=20 cprim=700 R=3 X=9

//Fase B
New Transformer.RegFaseB phases=1 xhl=0.01 %LoadLoss=0.001
~ wdg=1 bus=650.2 kV=2.4 kva=1666.7
~ wdg=2 bus=Reg.2 kV=2.4 kva=1666.7
New regcontrol.RegFaseB transformer=RegFaseB
~ winding=2 vreg=122 band=2 ptratio=20 cprim=700 R=3 X=9

//Fase C
New Transformer.RegFaseC phases=1 xhl=0.01 %LoadLoss=0.001
~ wdg=1 bus=650.3 kV=2.4 kva=1666.7
~ wdg=2 bus=Reg.3 kV=2.4 kva=1666.7
New regcontrol.RegFaseC transformer=RegFaseC
~ winding=2 vreg=122 band=2 ptratio=20 cprim=700 R=3 X=9
//-----//
```

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss transformer.dss regulators.dss switches.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\regulators.dss

Summary Results

Memory: 25416K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5

# SWITCHES

File Edit Do Set Make Export Show Visualize Plot Reset Help

Source/Fault | Vsource | Base Frequency = 60 Hz

C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\MASTER\_RedeTeste13Barras. Warning: Duplicate new element definition: "Transformer.Subestacao"E

Results for Actor ID # 1

CPU selected : 0  
 Status = SOLVED  
 Solution Mode = Daily  
 Number = 24  
 Load Mult = 1.000  
 Devices = 45  
 Buses = 17  
 Nodes = 44  
 Control Mode = STATIC  
 Total Iterations = 13  
 Control Iterations = 3  
 Max Sol Iter = 5

- Circuit Summary -

Year = 0  
 Hour = 24  
 Max pu. voltage = 1.0588  
 Min pu. voltage = 0.99057  
 Total Active Power: 2.40879 MW  
 Total Reactive Power: 0.881568 Mvar  
 Total Active Losses: 0.0530838 MW, (2.204 %)  
 Total Reactive Losses: 0.145279 Mvar  
 Frequency = 60 Hz  
 Mode = Daily  
 Control Mode = STATIC  
 Load Model = PowerFlow

```
//-----//
// Switch
New Line.671692 Phases=3 Bus1=671 Bus2=692 Switch=y
//-----//
```

Main MASTER\_RedeTeste13Barras.dss lines.dss loadshape.dss loads.dss pvsystemexample.dss transformer.dss regulators.dss switches.dss

Messages OpenDSS - C:\Users\HP\Desktop\openDSS\Paulo\_Example\DSSFiles\switches.dss

Summary Results

Memory: 25416K Circuit Status: SOLVED Total Iterations = 13, Control Iterations = 3, Max Solution Iterations = 5